



Department of Public Works  
**City Engineering Division**

608 266 4751

Robert F. Phillips, P.E.  
**City Engineer**

City-County Building, Room 115  
210 Martin Luther King, Jr. Boulevard  
Madison, Wisconsin 53703  
FAX 608 264 9275  
Textnet 866 704 2315  
www.cityofmadison.com

**Assistant City Engineer**  
Michael R. Dailey, P.E.

**Principal Engineers**  
Christina M. Bachmann, P.E.  
John S. Fahrney, P.E.  
Gregory T. Fries, P.E.  
Christopher J. Petykowski, P.E.

**Facilities & Sustainability**  
Jeanne E. Hoffman, Manager  
James C. Whitney, A.I.A.

**Operations Supervisor**  
Kathleen M. Cryan

**GIS Manager**  
David A. Davis, R.L.S.

**Financial Officer**  
Steven B. Danner-Rivers

**Hydrogeologist**  
Brynn Bemis

June 27, 2012

## NOTICE OF ADDENDUM

### CONTRACT 6875

### ENGINEERING SERVICE BUILDING PV SYSTEM - 2012

#### ADDENDUM NO. 1

Changes to Specifications section 26 60 00:

1. Change in number and type of PV panels: use 78 245W-panels (total 19.11 kW) from any of the approved manufacturers
2. Clarification for array length: array length limited to 40' to allow enough space for service. Some portion of roof may allow larger arrays upon approval by structural engineer
3. Expanded panel manufacturers: allowed PV panel manufacturers are Sunpower, Sharp, Solarworld, and Kyocera
4. Install 2 permanent roof davits (roof currently does not have safety anchors)

Electronic version of these documents can be obtained at any of the following online locations:

City of Madison Public Works Project Notices:

<http://www.cityofmadison.com/business/PW/contracts/openforBid.cfm>

If you are unable to download any forms associated with the addendum, please contact the Engineering office at 608-266-4751 to receive the material by another method.

Robert F Phillips, City Engineer