



Department of Public Works  
**City Engineering Division**  
Robert F. Phillips, P.E.  
**City Engineer**

**608 266 4751**

City-County Building, Room 115  
210 Martin Luther King, Jr. Boulevard  
Madison, Wisconsin 53703  
FAX 608 264 9275  
Textnet 866 704 2315  
www.cityofmadison.com

**Assistant City Engineer**  
Michael R. Dalley, P.E.

**Principal Engineers**  
Christina M. Bachmann, P.E.  
John S. Fahrney, P.E.  
Gregory T. Fries, P.E.  
Christopher J. Petykowski, P.E.

**Facilities & Sustainability**  
Jeanne E. Hoffman, Manager  
James C. Whitney, A.I.A.

**Operations Supervisor**  
Kathleen M. Cryan

**GIS Manager**  
David A. Davis, R.L.S.

**Financial Officer**  
Steven B. Danner-Rivers

**Hydrogeologist**  
Brynn Bemis

June 29, 2012

**NOTICE OF ADDENDUM**

**Contract 6875**

**Engineering Service Building PV System - 2012**

**ADDENDUM NO. 2**

1. Bid submittal deadline will be extended to July 6<sup>th</sup> 2012 at 1:00 p.m.
2. Bid opening date won't be changed and will remain July 6<sup>th</sup> 2012.
3. Changes to Specifications section 26 60 00:
  - a. All steel structure elements shall be made of hot-dipped galvanized steel (G90 coating)
  - b. Two permanent roof anchors shall be installed for fall protection. Anchors shall be installed on tip of roof or as required by OSHA. Anchors needs to be galvanized. A davit (required in addendum 1) is not required anymore.

Electronic version of these documents can be obtained at any of the following online locations:

City of Madison Public Works Project Notices:

<http://www.cityofmadison.com/business/PW/contracts/openforBid.cfm>

If you are unable to download any forms associated with the addendum, please contact the Engineering office at 608-266-4751 to receive the material by another method.

Robert F Phillips, City Engineer