



Department of Public Works  
**City Engineering Division**

Robert F. Phillips, P.E.  
**City Engineer**

City-County Building, Room 115  
210 Martin Luther King, Jr. Boulevard  
Madison, Wisconsin 53703  
FAX 608 264 9275  
www.cityofmadison.com

**608 266 4751**

**Assistant City Engineer**  
Michael R. Dailey, P.E.

**Principal Engineers**  
Christina M. Bachmann, P.E.  
John S. Fahrney, P.E.  
Gregory T. Fries, P.E.  
Christopher J. Petykowski, P.E.

**Facilities & Sustainability**  
Jeanne E. Hoffman, Manager  
James C. Whitney, A.I.A.

**Operations Supervisor**  
Kathleen M. Cryan

**GIS Manager**  
David A. Davis, R.L.S.

**Financial Officer**  
Steven B. Danner-Rivers

**Hydrogeologist**  
Brynn Bemis

**NOTICE OF ADDENDUM**

**ADDENDUM NO. 1**

**CONTRACT NO. 6889**

**Change in payment responsibility for restriping. Change in specification for Water Repellents, and Expansion Joint Sealant System and compression seal.**

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.


1. Specification page D-5, Section 1.06 "Contractor Use of Public Rights-of-Way" item F, revise to say the City shall restripe pavement at City's expense.
2. Specification Section 07 19 00 Water Repellents, Section 1.04 Submittals, item B. Warranty (1.)(b.) eliminate requirement for absorption of less than 250 parts per million of chloride ions at the 1½" level for the 5 year warranty period for the 40% solids silane sealer. Sealer manufacturer shall however warrant that treated surfaces shall maintain the water repellent effect for sound concrete for the period of the warranty.
3. Specification Section 07 95 01 Expansion Joint Sealant System, Part-2 Products, Section 2.01 Materials. Item B. add Erie Metal Specialties CR-Series expansion joint for the Government East parking structure. Item E. add Erie Metal Specialties BR-Series compression seal replacement for the Capitol Square North parking structure.

Please acknowledge this addendum on page E1 of the contract documents.

Electronic version of these documents can be found on the City of Madison web site at:

<http://www.cityofmadison.com/business/PW/contracts/openforBid.cfm>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

  
David C. Dryer, P.E., City Traffic Engineer