

play
**MADISON
PARKS**

Kevin Briski
Madison Parks Superintendent

Madison Parks Division
www.cityofmadison.com/parks

Administrative Office
Planning and Development
Community & Recreation Services
210 ML King, Jr. Blvd. Rm. 104
P.O. Box 2987
Madison, WI 53701-2987
Phone: 608.266.4711
Fax: 608.267.1162

Parks Operations Offices
Goodman Maintenance Facility
1402 Wingra Creek Pkwy.
West Parks, 608.266.9214
Summit, 608.288.6164
West Forestry, 608.266.4816
Construction, 608.266.6289
Conservation, 608.267.4918

Sycamore Maintenance Facility
4602 Sycamore Ave.
East Parks, 608.246.4508
East Forestry, 608.266.4816

Olbrich Botanical Gardens
3330 Atwood Ave., 608.246.4550

Warner Park Community
Recreation Center
1625 Northport Dr., 608.245.3690

Irwin A. & Robert D. Goodman Pool
325 Olin Ave., 608.264.9292

Golf Madison Parks
Supervisor, 608.838.3920
Glenway Golf Course
3747 Speedway Rd., 608.266.4737
Monona Golf Course
111 East Dean Ave., 608.266.4736
Odana Hills Golf Course
4635 Odana Rd., 608.266.4724
Yahara Hills Golf Course
6701 E. Broadway, 608.838.3126

State Street Mall/Concourse
Maintenance
211 S. Fairchild St., 608.266.6031

Forest Hill Cemetery
1 Speedway Rd., 608.266.4720



A Proud Division of
the City of Madison

NOTICE OF ADDENDUM
ADDENDUM NO. 1
BREESE STEVENS FIELD LIGHTING/SOUND SYSTEM IMPROVEMENTS
CONTRACT NO. 7044

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

1. Section 16740 – Athletic Field Sound Systems, Page 16740-9, Paragraph 2.02-C:

- CHANGE the loudspeaker wire model number in paragraph 5 from “16-2C-P-WHT” to “10-2C-EX+”.
- ADD the following paragraph 6:
 - “6. For both amplified loudspeaker channels in the Amplifier Rack, provide a loudspeaker line lightning suppressor mounted inside the rack and wired to each amplifier output channel. Loudspeaker line lightning suppressor shall be Grommes-Precision Model SLS, or equal.

2. **Section 105.12 COOPERATION OF THE CONTRACTOR:**

Add the following paragraph:

If the contractor chooses to set up a crane to do this work on the street side of the wall, the contractor will have to coordinate, apply and pay for a Street Occupancy Permit from the City of Madison Traffic Engineering Division. All costs associated with acquiring this permit must be included in the base bid.

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder’s Acknowledgement on Bid Express.

Electronic version of these documents can be found on Bid Express at <https://www.bidexpress.com/> and the City of Madison web site at <http://www.cityofmadison.com/business/PW/contracts/openforBid.cfm>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 to receive the material by another route.

Kevin Briski – Superintendent of Parks