

Quality and Reliability since 1882

**Madison
Water
Utility**



www.madisonwater.org • 119 East Olin Avenue • Madison, WI 53713-1431 • TEL 608.266.4651 • FAX 608.266.4426

November 6, 2013

**NOTICE OF ADDENDUM
ADDENDUM NO. 1
CONTRACT NO. 7107**

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

There is a conflict between the plans and the specifications regarding driveway pavement thickness. Sheet C-2, including the typical pavement section detail, calls for 4-inch total pavement thickness while the specification Section 32 10 00.13 Roads, Driveways and Walks specifies 3-1/2-inch total pavement thickness. **The specifications shall prevail.**

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on Bid Express at <https://www.bidexpress.com>.

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

Alan L. Larson, PE, BCEE
Principal Engineer