



Department of Public Works

Engineering Division

Robert F. Phillips, P.E., City Engineer

City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4751
Fax: (608) 264-9275
engineering@cityofmadison.com
www.cityofmadison.com/engineering

Assistant City Engineer

Michael R. Dailey, P.E.

Principal Engineers

Christina M. Bachmann, P.E.

John S. Fahrney, P.E.

Gregory T. Fries, P.E.

Christopher J. Petykowski, P.E.

Facilities & Sustainability

Jeanne E. Hoffman, Manager

Operations Manager

Kathleen M. Cryan

Mapping Section Manager

Eric T. Pederson, P.S.

Financial Manager

Steven B. Danner-Rivers

Hydrogeologist

Brynn Bemis

June 25, 2014

NOTICE OF ADDENDUM NO. 2 CONTRACT NO. 7343

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

1. Drawing sheet E100: replace sheet in its entirety with the following additions
 - a) UPS, Scanner and Strobes by others
 - b) Provide 1 (one) 20A duplex receptacle (dedicated circuit) w/ circuit breaker handle lock on North wall-West side of room104
 - c) Provide 1 (one) 19" IT rack w/ pedestal floor feet and supporting wall hardware near new duplex receptacle.
 - d) Provide racking for 2 (two) RU devices.
 - e) Provide 1 (one) ½" conduit from rack in room 104 to ceiling box in center of room 101 and extend ½" conduit to wall box outside between doors on East elevation.
 - f) Install 1 (one) separate 2 cond-18 Ga cable from rack to each strobe box.
 - g) Terminations and testing by others.
2. Spec Section 26 05 19 Low Voltage Wires, Part 2 – Products, 2.2 Communication Cables: ADD item "D. Hazardous Warning System"

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:

<http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

Robert F. Phillips, P.E., City Engineer

assemblage
ARCHITECTS


7427 Elmwood Avenue
Middleton, WI 53562
T 608.827.5047
F 608.827.6960

ARNOLD & O'SHERIDAN, INC.
726 HEARTLAND TRAIL
MADISON, WI 53717

T/ 608 821 8500
F/ 608 821 8501
A&O PROJECT #130158

HIGHLAND MANOR COMMUNITY SAFE ROOM
CITY OF MADISON - CONTRACT NO. 7104
10 MANOR DRIVE
MADISON, WISCONSIN

SHEET NAME
ELECTRICAL FLOOR PLANS



CITY OF MADISON
Contract: 7343

REVISION	DATE
ADDENDUM 2	6-24-14

PROJECT NO 1307

SET TYPE BID DOCUMENTS

DATE 05-30-2014

SHEET NUMBER

E100

