



Department of Public Works
Engineering Division
Robert F. Phillips, P.E., City Engineer

City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4751
Fax: (608) 264-9275
engineering@cityofmadison.com
www.cityofmadison.com/engineering

Assistant City Engineer
Michael R. Dailey, P.E.

Principal Engineer 2
Gregory T. Fries, P.E.
Christopher J. Petykowski, P.E.

Principal Engineer 1
Christina M. Bachmann, P.E.
Eric L. Dundee, P.E.
John S. Fahrney, P.E.

Facilities & Sustainability
Jeanne E. Hoffman, Manager

Operations Manager
Kathleen M. Cryan

Mapping Section Manager
Eric T. Pederson, P.S.

Financial Manager
Steven B. Danner-Rivers

August 5, 2016

NOTICE OF ADDENDUM
ADDENDUM NO. 1

CONTRACT NO. 7782, MUNIS 10121
ESTHER BEACH PARK SHELTER

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

Page D-6 Section 108.2 Permits

Item #3 - City of Madison Sanitary Plug Permit

This permit was not included in Exhibit E of the packet, but has been applied for with Site and Parking Lot submission to City Zoning.

Page 32 12 16-1 Asphalt Paving

Remove Part 2 – Products and Part 3 – Execution.

Refer to City of Madison Standard Specifications for Public Works Construction – 2016 Edition

Page 32 33 00-1 Site Furnishings, Section A. Bicycle Racks

Omit this section. Note that Bike Rack is described in Section D Special Provisions (page D-9) and on drawing C3.0; Saris Model 2451.

Page 32 92 00-1 Turf and Grasses

Remove Part 2 – Products and Part 3 – Execution.

Refer to City of Madison Standard Specifications for Public Works Construction – 2016 Edition

Question by contractor:

With no room finish schedule, do only rooms 102 and 103 get the epoxy flooring? How high is cove base?

Answer: Yes, only the two restrooms 102 and 103 get epoxy flooring.
The cove base is 6" high.

For questions regarding this bid, contact:

Jeanine Zwart
City of Madison Engineering
Phone: 608-267-8749

Email: jzwart@cityofmadison.com


Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:

<http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

Sincerely,


for Robert F. Phillips, P.E., City Engineer

Cc: Mike Dailey