



Department of Public Works
Engineering Division
Robert F. Phillips, P.E., City Engineer

City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4751
Fax: (608) 264-9275
engineering@cityofmadison.com
www.cityofmadison.com/engineering

Assistant City Engineer

Gregory T. Fries, P.E.
Kathleen M. Cryan

Principal Engineer 2

Christopher J. Petykowski, P.E.
John S. Fahrney, P.E.

Principal Engineer 1

Christina M. Bachmann, P.E.

Facilities & Sustainability

Jeanne E. Hoffman, Manager

Mapping Section Manager

Eric T. Pederson, P.S.

Financial Manager

Steven B. Danner-Rivers

December 19, 2017

**NOTICE OF ADDENDUM
ADDENDUM NO. 3
CONTRACT NO. 7974**

MONROE STREET ASSESSEMENT DISTRICT - 2018

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

SPECIAL PROVISIONS:

ADD TO BID ITEM - 90079 PRECAST CONCRETE SIDEWALK PANEL:

Precast Concrete Sidewalk Panels shall be 6 Inches thick.

PROPOSAL:

See below for a summary of item quantities that have been revised. Refer to the proposal for updated quantities.

ITEMS:

Action	Bid Item	Description	Original Qty.	New Qty.
MODIFY	90054	SHRUBS	52 EACH	8 EACH
MODIFY	90056	PERENNIALS & GRASSES, 1 GAL., CONT.	280 EACH	295 EACH

INFORMATIONAL ITEMS ONLY:

Addition questions from contractors and responses are below:

Q: Is there a specific manufacturer or catalog number for the metal cabinets within the mosaic wall?

A: No. The required dimensions are specified, and if no prefabricated can be found meeting the details and specifications, the cabinet may need to be custom built.

Q: Is there a thickness and specific manufacturer/product for the precast concrete panels?

December 19, 2017

A: The precast concrete panels shall be 6-Inches thick. The City had previously used the Replenish product made by Spancrete, but any precast panels meeting the specified criteria would be acceptable.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert Phillips". The signature is written in a cursive style with large, sweeping loops.

Robert F. Phillips, P.E.
City Engineer

RFP:JMW