

Department of Public Works
Engineering Division
Robert F. Phillips, P.E., City Engineer

City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4751
Fax: (608) 264-9275
engineering@cityofmadison.com
www.cityofmadison.com/engineering

Deputy City Engineer
Gregory T. Fries, P.E.

Deputy Division Manager
Kathleen M. Cryan

Principal Engineer 2
Christopher J. Petykowski, P.E.
John S. Fahrney, P.E.

Principal Engineer 1
Christina M. Bachmann, P.E.
Mark D. Moder, P.E.
Janet Schmidt, P.E.
James M. Wolfe, P.E.

Facilities & Sustainability
Bryan Cooper, Principal Architect

Mapping Section Manager
Eric T. Pederson, P.S.

Financial Manager
Steven B. Danner-Rivers

March 3, 2020

**NOTICE OF ADDENDUM
ADDENDUM NO. 1
CONTRACT NO. 8121**

ALLEYS RECONSTRUCTION ASSESSMENT DISTRICT - 2020

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

SPECIAL PROVISIONS:

ADD TO BID ITEM 90001 – PRECAST PERVIOUS CONCRETE PAVEMENT

Precast Pervious Concrete Panels shall be interlocking, tongue and groove connections, such that the panels remain fixed in placed once set. Additional or alternative methods of connecting panels shall be approved by the Engineer prior to installation.

ADD TO BID ITEM 90003 – 1” CLEAR STONE

1” Clear Stone shall be used to backfill any undercut areas under the pervious pavement area. This includes where additional excavation cut is performed to grade down to the sand layer.


Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:

<http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

Sincerely,



FOR Robert F. Phillips, P.E.
City Engineer