



Department of Transportation

## Traffic Engineering and Parking Divisions

Yang Tao, City Traffic Engineer

Sabrina Tolley, Assistant Parking Utility Manager

Madison Municipal Building, Suite 109

215 Martin Luther King, Jr. Blvd.

P.O. Box 2986

Madison, WI 53701-2986

Phone: (608) 266-4761 | Fax: (608) 267-1158

[traffic@cityofmadison.com](mailto:traffic@cityofmadison.com)

[parking@cityofmadison.com](mailto:parking@cityofmadison.com)

April 21, 2020

### NOTICE OF ADDENDUM ADDENDUM 1

#### CONTRACT NO. 8885 2020 Parking Garage Maintenance

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:

<http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

Sabrina J. Tolley

Assistant City Parking Utility Manager

**ADDENDUM NO. 1**  
**City of Madison, Engineering Division**

**CONTRACT NO. 8885**  
**2020 Parking Garage Maintenance**

This addendum is issued to modify, explain or correct the original Drawings, Specifications, or Contract Documents of the subject contract and is hereby made a part of the contract documents.

**A. SPECIFICATIONS –**

- A. 01 22 00 – 3 1.2, C. 14: ADD “At OC, widening with care of existing joint is required due to post tensioning; provide concrete removal of 1-inch deep by 5/8-inch wide (maximum) on each side of joint as necessary for a total minimum joint width of 1 ¼-inch.”.
- B. 01 22 00 – 3 1.2, C. 19: DELETE “of concrete slabs or double tees and application of sealer at State Street Frances.” ADD “and application of sealer at State Street Frances to elevated structural slabs, double tees and 6-inches of adjacent vertical concrete surfaces.”.
- C. 07 95 07 – 3 2.1, B.: DELETE “Type TCR”.