



Department of Public Works  
**Engineering Division**  
Robert F. Phillips, P.E., City Engineer  
City-County Building, Room 115  
210 Martin Luther King, Jr. Boulevard  
Madison, Wisconsin 53703  
Phone: (608) 266-4751  
Fax: (608) 264-9275  
[engineering@cityofmadison.com](mailto:engineering@cityofmadison.com)  
[www.cityofmadison.com/engineering](http://www.cityofmadison.com/engineering)

**Assistant City Engineer**  
Michael R. Dailey, P.E.

**Principal Engineers**  
Christina M. Bachmann, P.E.  
John S. Fahrney, P.E.  
Gregory T. Fries, P.E.  
Christopher J. Petykowski, P.E.

**Facilities & Sustainability**  
Jeanne E. Hoffman, Manager

**Operations Manager**  
Kathleen M. Cryan

**Mapping Section Manager**  
Eric T. Pederson, P.S.

**Financial Manager**  
Steven B. Danner-Rivers

**Hydrogeologist**  
Brynn Bemis

March 25, 2014

**NOTICE OF ADDENDUM-2**  
**UNIT WELL NO. 7 RECONSTRUCTION AND FILTER ADDITION**  
**CONTRACT NO. 7265**

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

A. DRAWINGS

1. SHEET NO. 8–OVERALL SITE PLAN

CLARIFICATION: The street patch on Sherman Avenue shall conform to the City of Madison’s patching requirements for streets with pavement ratings greater than 6. The patch shall be a minimum of 50 feet in length and shall extend a minimum of 15 feet beyond the edges of the excavation. See patching criteria for patch width. Saw cut pavement at utility opening. Mill and overlay patched areas beyond the trench. Any pavement markings disturbed by activities shall be replaced with new epoxy pavement markings to match existing.

CLARIFICATION: Any street patches on Schligen Avenue shall be saw cut square and patched. Pavement rating on Schligen Avenue is 5.

2. SHEET NO. 12–SITE DETAILS

CHANGE the binder course to 2.25 inches and the surface course to 1.75 inches in the NEW PAVEMENT SECTION, DETAIL D/C5.1.

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder’s Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:

<http://www.bidexpress.com>

---

---

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 to receive the material by another route.

---

---

Alan L. Larson, PE, BCEE  
Principal Engineer



*Scott G. Herkert*  
3-25-14