



Department of Public Works  
**Engineering Division**  
Robert F. Phillips, P.E., City Engineer

City-County Building, Room 115  
210 Martin Luther King, Jr. Boulevard  
Madison, Wisconsin 53703  
Phone: (608) 266-4751  
Fax: (608) 264-9275  
[engineering@cityofmadison.com](mailto:engineering@cityofmadison.com)  
[www.cityofmadison.com/engineering](http://www.cityofmadison.com/engineering)

**Assistant City Engineer**  
Michael R. Dailey, P.E.

**Principal Engineer 2**  
Gregory T. Fries, P.E.

**Principal Engineer 1**  
Christina M. Bachmann, P.E.  
Eric L. Dundee, P.E.  
John S. Fahrney, P.E.  
Christopher J. Petykowski, P.E.

**Facilities & Sustainability**  
Jeanne E. Hoffman, Manager

**Operations Manager**  
Kathleen M. Cryan

**Mapping Section Manager**  
Eric T. Pederson, P.S.

**Financial Manager**  
Steven B. Danner-Rivers

March 24, 2015

**NOTICE OF ADDENDUM  
ADDENDUM 1  
QUANN PARK TENNIS COURT  
RECONSTRUCTION PHASE 2  
CONTRACT NO. 7475**

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

**Delete original DESCRIPTION for BID ITEM # 90008 CONTROL JOINTS**

**Insert the following revised DESCRIPTION for BID ITEM #90008 CONTROL JOINTS:**

**DESCRIPTION**

The contractor shall saw control joints in the new bituminous pavement at locations shown on the plans. Sawed joints shall be blown free of dust and debris with compressed air. Compressed air equipment shall deliver at least 80 psi to the joint for cleaning.

The sawed line shall not vary more than one inch (1") in 30 feet from a straight line and shall be perpendicular to the runway centerline.

All discarded materials, including any excess filler coat or finish coat material dumped on the lawn, shall be cleaned up from around the work site. Any ruts caused by vehicles or work equipment shall be repaired.

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:

<http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

  
Eric Knepp, Parks Superintendent