

Madison Public Library Support Center

Addendum #3

2/7/2017

Item	Sheet
Sectional Doors: 2" specified (Sec 2.02), but 3" door (OH Door Co model 850) called out. See Sec 2.01 . Removed reference to Overhead Door product. Doors that meet the specifications are allowable. Clopay 3220 door is basis of design.	Specification 08 36 13
Sheet metal flashing: Sections revised to require 0.05" thick pre-finished aluminum.	Specification 07 62 00 (section 2.04)
Included Vapor Barrier definition in roof specs	Specification 07 53 00