



Department of Public Works
Engineering Division
Robert F. Phillips, P.E., City Engineer

City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4751
Fax: (608) 264-9275
engineering@cityofmadison.com
www.cityofmadison.com/engineering

Assistant City Engineer
Michael R. Dailey, P.E.

Principal Engineer 2
Gregory T. Fries, P.E.
Christopher J. Petykowski, P.E.

Principal Engineer 1
Christina M. Bachmann, P.E.
Eric L. Dundee, P.E.
John S. Fahrney, P.E.

Facilities & Sustainability
Jeanne E. Hoffman, Manager

Operations Manager
Kathleen M. Cryan

Mapping Section Manager
Eric T. Pederson, P.S.

Financial Manager
Steven B. Danner-Rivers

July 22, 2016

NOTICE OF ADDENDUM

ADDENDUM 1

MONONA TERRACE FIRE ALARM SYSTEM UPGRADE

CONTRACT NO. 7730

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

1. In Specification Section 26 31 00 - Fire Alarm System, 2.03.B. the list of approved manufacturers shall be amended to include Gamewell - FCI, series E3 and Edwards - Kidde, model EST3.
2. Specification Section 26 31 00 - Fire Alarm System, 3.02.D and 3.02.E. shall be clarified as follows: Each existing elevator recall and shunt trip operation shall interface with the new Fire Alarm Control panel. Provide additional programming, conduit and wire as required.

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:

<http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

Robert F. Phillips, P.E., City Engineer