



"A" - ELECTRICAL BONDING: CONNECT OUTSIDE THE METER COUPLINGS
 - METER BYPASS PIPING IS NOT PERMITTED

"B" - METER LAY LENGTH (BY METER SIZE):
 (DOES NOT INCLUDE GASKET OR COUPLING)

$\frac{5}{8}$ "	=	7 $\frac{1}{2}$ "
$\frac{3}{4}$ "	=	9"
1"	=	10 $\frac{3}{4}$ "

"C" - REQUIRED CLEAR WIDTH:

$\frac{5}{8}$ "	=	12 $\frac{1}{4}$ "
$\frac{3}{4}$ "	=	14"
1"	=	16"

CITY OF MADISON
 WATER UTILITY

NOT TO SCALE

STANDARD 5/8", 3/4", 1" METER INSTALLATION