



Department of Planning & Community & Economic Development
Planning Division

Website: www.cityofmadison.com

Madison Municipal Building
215 Martin Luther King, Jr. Boulevard
P.O. Box 2985
Madison, Wisconsin 53701-2985
TDD 608 266-4747
FAX 608 266-8739
PH 608 266-4635

September 15, 2009

Gary Brown
UW-Madison Facilities Planning & Management
610 Walnut St.
Madison, WI 53726

RE: Approval of the demolition of two buildings and a conditional use request for the construction of an addition to the University of Wisconsin-Madison Human Ecology Building including a daycare facility in the R5 (General Residence) District.

Dear Mr. Brown:

The Plan Commission, meeting in regular session on September 14, 2009 determined that the ordinance standards could be met and **approved** your request for a demolition permit and conditional use at 1300 Linden Drive. In order to receive final approval for the demolition permit and conditional use, the following conditions must be met:

Please contact my office at 266-5974 with questions about the following item:

1. The applicant will submit final plans with a clear designation of automobile parking stalls reserved for the preschool facility, as well as the location of moped stalls. Final plans may show greater than five moped stalls, as long as this does not result in a decrease in the number of bicycle stalls.

Please contact Janet Dailey, City Engineering, at 261-9688 with questions about the following six (6) items:

2. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
3. The City of Madison is an approved agent of the Department of Commerce. This proposal contains a commercial building and as such, the City of Madison is authorized to review infiltration, stormwater management, and erosion control on behalf of the Department of Commerce. No separate submittal to Commerce or the WDNR is required.
4. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Specifically, this development is required to:
 - a) Detain the 2 & 10-year storm events
 - b) Control 40% TSS (20 micron particle) off of new paved surfaces
 - c) Complete an erosion control plan and complete weekly self-inspection of the erosion control practices and post these inspections to the City of Madison website – as required by Chapter 37 of the Madison General Ordinances

5. The Applicant shall submit, prior to plan sign-off, a digital CAD file (single file) to the Engineering Program Specialist in the Engineering Division (Lori Zenchenko). The digital CAD file shall be to scale and represent final construction. The single CAD file submittal can be either AutoCAD (dwg) Version 2001 or older, MicroStation (dgn) Version J or older, or Universal (dxf) format and contain only the following data, each on a separate layer name/level number.

PDF submittals shall contain the following information:

- a) Building footprints
 - b) Internal walkway areas
 - c) Internal site parking areas
 - d) Lot lines and right-of-way lines
 - e) Street names
 - f) Stormwater Management Facilities
 - g) Detail drawings associated with Stormwater Management Facilities (including planting plans)
6. The applicant shall submit, prior to plan sign-off, digital PDF files to the Engineering Division (Jeff Benedict or Tim Troester). The digital copies shall be to scale, and shall have a scale bar on the plan set.
 - a) SLAMM DAT files.
 - b) RECARGA files.
 - c) TR-55/HYDROCAD/Etc...
 - d) Sediment loading calculations

If calculations are done by hand or are not available electronically the hand copies or printed output shall be scanned to a PDF file and provided.

7. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size, invert elevation, and alignment of the proposed service.

Please contact John Leach, Traffic Engineering at 267-8755 with questions about the following item:

8. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), and a scaled drawing at 1" = 20'.

Please contact Pat Anderson, Zoning Administrator at 266-5978 with questions about the following six (6) items:

9. Lighting is not required. However, if it is provided, it must comply with City of Madsion General Ordinances Section 10.085 outdoor lighting standards (See parking lot packet). Lighting will be limited to .10 watts per square foot.
10. Provide adequate bicycle and scooter parking. Bike parking shall comply with City of Madison General Ordinances Section 28.11. Provide five bike parking stalls in a safe and convenient location on an impervious surface to be shown on the final plan. NOTE: A bike parking stall is two feet by six feet with a five-foot access area.
11. Meet all applicable State accessible requirements, including but not limited to:
 - a) Provide a minimum of two accessible stalls striped per State requirements in the parking garages with one van accessible stall striped per State requirements in the surface lot. A minimum of one of the surface stalls shall be a van accessible stall 8' wide with an 8' striped out area adjacent.
 - b) Show signage at the head of the stalls. Accessible signs shall be a minimum of 60" between the bottom of the sign and the ground.

- c) Show the accessible path from the stalls to the building. The stalls shall be as near the accessible entrance as possible. Show ramps, curbs, or wheel stops where required.
- 12. Signage approvals are not granted by the Plan Commission. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances and Chapter 33 Urban Design District ordinances. Signage permits are issued by the Zoning Section of the Department of Planning and Community and Economic Development.
- 13. Provide a reuse/recycling plan, to be reviewed and approved by the City's Recycling Coordinator, Mr. George Dreckmann, prior to demolition permit being issued. Section 28.12(12)(e) of the Madison General Ordinance requires the submittal of documentation demonstrating compliance with the approved reuse and recycling plan. Please note, the owner must submit documentation of recycling and reuse within 60 days of completion of demolition.
- 14. Parking and Loading shall comply with City of Madison General Ordinances Section 28.11(4). Provide two (2) 10' x 35' loading areas with 14' vertical clearance to be shown on the plan. The loading area shall be exclusive of drive aisle and maneuvering space. Meet with zoning staff to discuss options.

Please contact Scott Strassburg, Fire Department, at 261-9843 with questions about the following item:

- 15. Provide fire apparatus access as required by Comm 62.0509 and MGO 34.19, as follows:
 - a) The site plans shall clearly identify the location of all fire lanes.
 - b) Provide an aerial apparatus access fire lane that is at least 26-feet wide, with the near edge of the fire lane within 30-feet of the structure, and parallel to one entire side of the structure, if any part of the building is over 30 feet in height.
 - c) Provide a fire lane that extends to within 150-feet of all exterior portions of the structure, or it can be extended to within 250-feet if the building is fully sprinklered.
 - d) A dead-end fire lane that is longer than 150-feet shall terminate in a turnaround. Provide an approved turnaround (cul-de-sac, 45 degree wye, 90 degree tee) at the end of a fire lane that is more than 150-feet in length.
 - e) Per IFC 503.3 Show approved "fire lane, no parking" signs posted on the site plan. A max of 150-feet on center. Signs must be visual and easily read from any location on the fire lane. Fire lanes 20-27 feet wide will be posted as fire lane on both sides, 28-35 feet wide shall be posted fire lane on the appropriate side only.
 - f) Fire lanes shall be constructed of concrete or asphalt only, and designed to support a minimum load of 80,000 lbs

Please contact Dennis Cawley, Water Utility at 261-9243 with questions about the following item:

- 16. This property is not in a Wellhead Protection District, but all wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility.

Please now follow the procedures listed below for obtaining your demolition permit and conditional use permit:

1. Please revise your plans per the above and submit **eight (8) copies** of a complete plan set to the Zoning Administrator for final staff review and comment.
2. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting the demolition permit and conditional use permit.
3. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. This approval shall become null and void one year after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within six months of the issuance of said building permit. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved conditional use permit.

If you have any questions regarding obtaining your demolition permit or conditional use permit, please contact the Zoning Administrator at 266-4551. If you have any questions or if I may be of any further assistance, please do not hesitate to contact my office at 266-5974.

Sincerely,

I hereby acknowledge that I understand and will comply with the above conditions of approval for this conditional use permit.

Signature of Applicant

Heather Stouder, AICP
 Planner

- cc: Pat Anderson, Assistant Zoning Administrator
 Janet Dailey, City Engineering
 John Leach, Traffic Engineering
 George Dreckmann, Recycling Coordinator
 Scott Strassburg, Fire Department

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Division (H. Stouder)	<input checked="" type="checkbox"/>	Recycling Coordinator (R & R)
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Fire Department
<input checked="" type="checkbox"/>	City Engineering	<input type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Other:
<input checked="" type="checkbox"/>	Engineering Mapping	<input type="checkbox"/>	Other: