



Department of Planning & Development
Planning Unit

Website: www.cityofmadison.com

Madison Municipal Building
215 Martin Luther King, Jr. Boulevard
P.O. Box 2985
Madison, Wisconsin 53701-2985
TDD 608 266 4747
FAX 608 266-8739
PH 608 266-4635

November 8, 2005

Phillip Schmidt
Architectural Design Consultants
161 Horizon Drive #102
Verona, Wisconsin

RE: Approval of a demolition permit for a commercial building at 26 Schroeder Court.

Dear Mr. Schmidt:

The Plan Commission, meeting in regular session on November 7, 2005, determined that the ordinance standards could be met and **approved** your request for a demolition permit to demolish a former fitness facility located at 26 Schroeder Court and construct a new three-story retail/ office building, subject to the conditions below. In order to receive final approval of the demolition permit, the following conditions must be met:

Please contact Kathy Voeck, the Assistant Zoning Administrator, at 266-4551 if you have questions regarding the following four items:

1. Provide nine bike parking stalls in a safe and convenient location on an impervious surface to be shown on the final plan. The lockable enclosed lockers or racks or equivalent structures in or upon which the bicycle may be locked by the user shall be securely anchored to the ground or building to prevent the lockers or racks from being removed from the location. NOTE: A bike-parking stall is two feet by six feet with a five-foot access area. Structures that require a user-supplied locking device shall be designed to accommodate U-shaped locking devices.
2. Parking lot plans with greater than twenty (20) stalls, landscape plans must be stamped by a registered landscape architect. Provide a landscape worksheet with the final plans that shows that the landscaping provided meets the point and required tree ordinances. In order to count toward required points, the landscaping shall be within 15' and 20' of the parking lot depending on the type of landscape element. (Note: The required trees do not count toward the landscape point total.) Planting islands shall consist of at least 75% vegetative cover, including trees, shrubs, ground cover, and/or grass. Up to 25% of the island surface may be brick pavers, mulch or other non-vegetative cover. All plant materials in islands shall be protected from vehicles by concrete curbs. A landscape buffer of 30' is required to be shown along the US Hwy. 12 & 14 property boundary with landscaping details shown on the landscape plan.
3. Lighting is not required. However, if it is provided, it must comply with City of Madison outdoor lighting standards. (See Parking Lot packet available from the Zoning Administrator). Lighting will be limited to .10 watts per square foot.
4. The Plan Commission does not grant signage approvals. Signage must be reviewed for compliance with Chapter 31 Sign Codes of the Madison General Ordinances and Chapter 33 Urban Design District ordinances. The Zoning Section of the Department of Planning and Development must issue permits.

Please contact John Leach, Traffic Engineering, at 267-8755 if you have questions about the following nine items:

5. The applicant shall be responsible for securing all proper permits and approvals from any municipality or government unit having jurisdiction with the project. In particular, the applicant shall contact John Steiner, Wisconsin Department of Transportation (WisDOT) at 246-3862, with site plans sets of plans for review and approval. The applicant shall return a set of site plans or letter with WisDOT-approved copies to the City of Madison Traffic Engineering Division.
6. The applicant shall contact the Department of Planning and Development to comply with MGO Section 16.23(3)(d) – Highway Noise Land Use Provisions policies and ordinances.
7. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), adjacent driveway approaches to lots on either side and across the street, signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.
8. The applicant shall show all dimensions for proposed parking stalls' items A, B, C, D, E, and F, and for ninety-degree angle parking width and backing up, according to Figures II "Medium and Large Vehicles" and Figure III "Small Vehicle" parking design standards in Section 10.08(6)(b) 2 and 3.
 - The applicant shows 7.5 ft. parking spaces in the westerly park lot, these spaces shall be modified and dimension according to MGO.
 - Per ordinance, the small car stalls shall not exceed 25% of the total number of Medium and Large Vehicles and Small Vehicles stalls for the facility. The site plan shall show small car parking spaces identified and properly controlled with a sign "Small Cars Only" per each space, when plans are submitted for approval.
 - The applicant shall design the underground parking areas for stalls and backing up according to Figures II. The "One Size Fits All" stall could be used for the underground parking area only, which is a stall 8'-9" in width by 17'-0" in length with a 23'-0" backup. Aisles, ramps, columns, offices or work areas are to be excluded from these rectangular areas, when designing underground parking areas.
9. The applicant shall modify the driveway approach according to the design criteria for a "Class III" driveway in accordance to Madison General Ordinance Section 10.08(4).
 - The applicant shall modify the plan so no part of the driveway approaches shall extend in front of the property belonging to a person other than the permittee unless both property owners sign a joint application for a permit or driveway radii waiver letter prior to submittal of plans for approval.
 - The "Class 3" require sidewalk across the driveway approaches. The applicant proposed Flared Sidewalk Ramps to be modified to public sidewalk without ramps at the driveway approach.
 - The applicant shall modify the westerly driveway according to MGO 10.08(3)(b), No entrance shall be closer than five (5) feet to an adjacent property line.
10. "Stop" signs shall be installed at a height of seven (7) feet at the driveway approaches. All signs at the approaches shall be installed behind the property line. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
11. To provide for adequate bike & pedestrian pathways/linkage from the public sidewalk to the building entrance/ bike rack, the applicant shall modify the sidewalk to 8 feet in width public sidewalk to and in between the bike racks.

12. The Developer shall post a deposit or reimburse the City for all costs associated with any modifications to Street Lighting, Signing and Pavement Marking including labor and materials for both temporary and permanent installations.
13. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact Gary Dallmann, City Engineering, at 266-4751 if you have questions regarding the following ten items:

14. First floor tenants may have individual street addresses. Second and third floor tenants must use numeric whole suite numbers. Please contact Lori Zenchenko at 266-5952 for more information on site addressing.
15. Stormwater Management required includes 40% Total Suspended Solid (TSS) control and oil and grease control.
16. A City licensed contractor shall perform all work in the public right-of-way.
17. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5-tons per acre per year.
18. This site is greater than one (1) acre and the applicant is required by State Statute to obtain a Notice of Intent Permit (NOI) from the Wisconsin Department of Natural Resources (WDNR). Please contact Jim Bertolacini of the WDNR at 275-3201 to discuss this requirement.
19. Prior to approval, this project shall comply with Chapter 37 of the Madison General Ordinances regarding stormwater management. Please contact Greg Fries at 267-1199 to discuss this requirement.
20. The Applicant shall obtain a Street Excavation permit for the installation of utilities required to serve this project. The Applicant shall pay the permit fee, inspection fee and street degradation fee as applicable and shall comply with all the conditions of the permit.
21. The applicant shall obtain all necessary sewer connection permits and sewer plugging permits prior to any utility work.
22. Prior to approval of the conditional use application, the owner shall obtain a permit to plug each existing sanitary sewer lateral that serves a building that is proposed for demolition. For each lateral to be plugged the owner shall deposit \$1,000 with the City Engineer in two separate checks in the following amounts: (1). \$100 non-refundable deposit for the cost of inspection of the plugging by City staff; and (2). \$900 for the cost of City crews to perform the plugging. If the owner elects to complete the plugging of a lateral by private contractor and the plugging is inspected and approved by the City Engineer, the \$900 fee shall be refunded to the owner.
23. The Applicant shall submit, prior to plan sign-off, digital CAD files to the Land Records Coordinator in the Engineering Division (Lori Zenchenko). The digital copies shall be drawn to scale and represent final construction, including: building footprints, internal walkway areas, internal site parking areas, and other miscellaneous impervious areas.

Please contact John Lippitt, Madison Fire Department, at 261-9658 if you have questions about the following three items:

24. The fire lanes shown on the site plans do not comply with Comm 62.0509, and/or MGO Chapter 34; the owner must revise the plans or apply for and receive approval of a Petition for Variance from the Board of Building Code, Fire Code and Licensing Appeals prior to construction of the project. If the Board does not approve the Petition for Variance, then the owner must submit a new application for approval of revised plans.
25. All portions of the exterior walls of newly constructed public buildings and places of employment and open storage of combustible materials shall be within 500-feet of at least TWO fire hydrants. Distances are measured along the path traveled by the fire truck as the hoselay off the truck. See MGO 34.20 for additional information.
26. Provide fire apparatus access as required by Comm 62.0509 and MGO 34.19, as follows:
 - a. The site plans shall clearly identify the location of all fire lanes.
 - b. Provide an aerial apparatus access fire lane that is at least 26-feet wide, with the near edge of the fire lane within 30-feet of the structure, and parallel to one entire side of the structure.
 - c. Provide a fire lane that extends to within 150-feet of all exterior portions of the structure.
 - d. A dead-end fire lane that is longer than 150-feet shall terminate in a turnaround. Provide an approved turnaround (cul-de-sac, 45 degree wye, 90 degree tee) at the end of a fire lane that is more than 150-feet in length.
 - e. Fire lanes shall be constructed of concrete or asphalt only, and designed to support a minimum load of 80,000 lbs.
 - f. Provide a completed MFD "Fire Apparatus Access and Fire Hydrant Worksheet" with the site plan submittal.

Please contact my office at 261-9632 if you have questions about the following item:

27. That the landscaping plan be revised to include the planting of a continual line of shade trees along the northern 30 feet of the property. The line should include a mix of over-story trees planted no more than 50 feet on center along the length of the property line.

Approval of this project does not include any approval to prune, remove or plant trees in the public right of way. Permission for such activities must be obtained from the City Forester, 266-4816.

The Madison Water Utility shall be notified to remove the water meter prior to demolition.

The site is located within an Urban Design District and has been granted final approval by the Urban Design Commission (UDC). Compliance with any UDC conditions of approval shall be included with the plans submitted for final approval as noted below.

Please now follow the procedures listed below for obtaining your demolition permit:

1. A reuse and recycling plan approved by the Recycling Coordinator is required by ordinance prior to the issuance of wrecking permit.
2. Please revise your plans per the above and submit *eight (8) copies* of a complete plan set to the Zoning Administrator for final review and comment. Also be sure to include any additional materials requested by these departments for their approval prior to sign off.

- 3. This letter shall be signed by the applicant to acknowledge the conditions of approval and returned to the Zoning Administrator when requesting demolition and/or building permit approval.
- 4. No alteration of this proposal shall be permitted unless approved by the Plan Commission, provided, however, the Zoning Administrator may issue permits for minor alterations. This approval shall become null and void one year after the date of the Plan Commission unless the use is commenced, construction is under way, or a valid building permit is issued and construction commenced within six months of the issuance of said building permit. The Plan Commission shall retain jurisdiction over this matter for the purpose of resolving complaints against the approved demolition permit.

If you have any questions regarding obtaining your demolition or building permits, please contact the Zoning Administrator at 266-4551. If you have any questions or if you may be of any further assistance, please do not hesitate to contact my office at 261-9632.

Sincerely,

Timothy M. Parks
Planner

I hereby acknowledge that I understand and will comply with the above conditions of approval for this demolition permit. _____ <i>Signature of Applicant</i>
--

- cc: Kathy Voeck, Assistant Zoning Administrator
John Leach, Traffic Engineering
Gary Dallmann, City Engineer's Office
John Lippitt, Madison Fire Department

For Official Use Only, Re: Final Plan Routing			
<input checked="" type="checkbox"/>	Planning Unit (T. Parks)	<input type="checkbox"/>	Parks Division
<input checked="" type="checkbox"/>	Zoning Administrator	<input checked="" type="checkbox"/>	Fire Department
<input checked="" type="checkbox"/>	City Engineering	<input checked="" type="checkbox"/>	Urban Design Commission
<input checked="" type="checkbox"/>	Traffic Engineering	<input type="checkbox"/>	Other: