

Department of Planning & Development **Planning Unit**

Website: www.cityofmadison.com

Madison Municipal Building 215 Martin Luther King, Jr. Boulevard P.O. Box 2985 Madison, Wisconsin 53701-2985 TDD 608 266 4747 FAX 608 266-8739 PH 608 266-4635

June 21, 2005

Kenneth Lambrecht 5712 Raymond Road Madison, WI 53711

SUBJECT: 6510 Watts Road

Dear Mr. Lambrecht:

The Plan Commission, at its June 20, 2005 meeting, recommended approval of the zoning map amendment from Temporary Agriculture to C3 for your proposed veterinary clinic and pet boarding facility.

The Common Council will consider the matter at their July 7, 2005 meeting. If the Council amends any of the following comments from the reviewing departments, another letter will be sent.

In order to receive final approval of your proposal, the following conditions must be met:

PLEASE CONTACT JOHN LEACH, CITY TRAFFIC ENGINEERING, AT 266-4761 IF YOU HAVE QUESTIONS REGARDING THE FOLLOWING SEVEN ITEMS:

- 1. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement and stalls), adjacent driveway approaches to lots on either side and across the street, signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.
- 2. When site plans are submitted for approval, the developer shall move the driveway approach to align with the 30-foot joint driveway easement as recorded on the CSM.
- 3. "Stop" signs shall be installed at a height of seven (7) feet at all driveway approaches behind the property line and noted on the plan. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
- 4. The intersection shall be so designed so as not to violate the City's sight-triangle preservations requirement which states that on a corner lot no structure, screening or embankment of any kind shall be erected, placed, maintained or grown between the heights of 30 inches and 10-feet above the curb level or its equivalent within the triangle space formed by the two intersecting street lines or their projections and a line joining points on such street lines located a minimum of 25-feet from the street intersection in order to provide adequate vehicular vision clearance.
- 5. The applicant shall show the dimensions for existing and proposed surface/underground parking stalls' items A, B, C, D, E, and F, for parking width and backing up, according to Figures II

Mr. K. Lambrecht 6/21/05 Page 2

- "Medium and Large Vehicles" parking design standards in Section 10.08(6)(b)2. The applicant shall modify the facility so no street light pole is in the parking space area.
- 6. The developer shall post a deposit or reimburse the City for all costs associated with any modifications to Street Lighting, Signing and Pavement Marking including labor and materials for both temporary and permanent installations.
- 7. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

PLEASE CONTACT GARY DALLMANN, CITY ENGINEERING, AT 266-4751 IF YOU HAVE QUESTIONS REGARDING THE FOLLOWING THIRTEEN ITEMS:

- 8. The pet clinic building and daycare building will need a Struck Street address. Contact City Engineering.
- 9. A developer agreement is required for installation of public sewer and public sidewalk.
- 10. At the time of development each lot shall be subject to fees due as part of the Upper Badger Mill Impact Fee District.
- 11. The developer shall provide plans and calculations to City Engineering for review and approval showing compliance with Chapter 37 (MGO) for stormwater management. This site requires 80% sediment control, oil and grease control, and 100-year detention. The site is exempt from infiltration as an infill development.
- 12. The site plan shall be revised to show proposed utilities.
- 13. The site plan shall reflect a proper street address of the property as reflected by official City of Madison Assessor's and Engineering Division records.
- 14. All work in the public right-of-way shall be performed by a City licensed contractor.
- 15. The applicant shall demonstrate compliance with Section 37.07 and 37.08 of the Madison General Ordinances regarding permissible soil loss rates. The erosion control plan shall include Universal Soil Loss Equation (USLE) computations for the construction period. Measures shall be implemented in order to maintain a soil loss rate below 7.5 tons per acre per year.
- 16. The applicant shall submit, prior to plan sign-off, digital CAD files to the Engineering Program Specialist in the Engineering Division (Lori Zenchenko). The digital copies shall be to scale and represent final construction.

CAD submittals can be either AutoCAD (dwg), MicroStation(dgn) or Universal (dxf) formats and contain the following data, each on a separate layer name/level number:

- a. Building Footprints
- b. Internal Walkway Areas
- c. Internal Site Parking Areas
- d. Other Miscellaneous Impervious Areas (i.e. gravel, crushed stone, bituminous/asphalt, concrete, etc.)

Note: Email file transmissions preferred: lzenchenko@cityofmadison.com

Mr. K. Lambrecht 6/21/05 Page 3

- 17. The applicant shall obtain a Street Excavation permit for the installation of utilities required to serve this project. The applicant shall pay the permit fee, inspection fee and street degradation fee as applicable and shall comply with all the conditions of the permit.
- 18. The applicant shall obtain all necessary sewer connection permits and sewer plugging permits prior to any utility work.
- 19. All outstanding Madison Metropolitan Sewerage District (MMSD) sanitary sewer connection charges are due and payable prior to connection to the public sewerage system.
- 20. The site plan shall be revised to show all existing public sanitary sewer facilities in the project area as well as the size and alignment of the proposed service.

PLEASE CONTACT KATHY VOECK, THE ASSISTANT ZONING ADMINISTRATOR, AT 266-4551 IF YOU HAVE QUESTIONS REGARDING THE FOLLOWING ITEM:

21. The final site plan-parking lot plan shall be reviewed and approved by City staff.

PLEASE CONTACT PLANNING UNIT STAFF AT 266-4635 IF YOU HAVE QUESTIONS REGARDING THE FOLLOWING ITEM:

22. The Planning Unit had <u>no conditions</u> of approval.

Approval of this proposal does not include any approval to prune, remove or plant trees in the public right-of-way. Permission for such activities must be obtained from the City Forester, 266-4816. The trees shown in the street rights-of-way shall not be shown on the sign-off plan or construction plans unless they have previously been approved by the City Forester. If these are existing trees or species and locations that have been approved by the Forester, they shall be so labeled on plans.

Please follow the procedures listed below to receive your conditional use approval.

1. Please revise plans per the above conditions and submit seven (7) sets of the final site plans (including drainage and landscaping plans) to the Zoning Administrator. In addition to these five sets of plans, please submit enough plans for each reviewing agency. The final plans are reviewed and approved by Traffic Engineering, Fire Department, City Engineering, and Zoning. Any of these agencies may call you to request additional information or to resolve problems.

IF YOU HAVE ANY QUESTIONS REGARDING OBTAINING YOUR BUILDING PERMIT OR OCCUPANCY PERMIT, PLEASE CALL KATHY VOECK OF THE CITY ZONING STAFF AT 266-4551.

Sincerely,		I hereby acknowledge that I understand and will comply with the above conditions of approval for this conditional use.	
Bill Roberts			
Planning & Development	Applicant	Zoning	
cc: Zoning Administrator		City Engineering	
City Engineering		Traffic Engineering	
Traffic Engineering			

Dynatron Research Foundation, 6743 Bayshore Drive, Egg Harbor, WI 54209