

**CITY OF MADISON
MADISON WATER UTILITY
119 East Olin Avenue
266-4651**

MEMORANDUM

Date: July 1, 2009

To: The Plan Commission
From: Dennis M. Cawley, Engineer 4 - Water Utility
Subject: CONDITIONAL USE – 5202 Cottage Grove Road

The Madison Water Utility has reviewed this conditional use and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS

The proposed water service lateral off Kingsbridge Road shall be constructed of Class 52 ductile iron pipe.

GENERAL OR STANDARD REVIEW COMMENTS

This property is not in a Wellhead Protection District.

All wells located on this property shall be abandoned if no valid well operation permit has been obtained from the Madison Water Utility.

The Water Utility will not need to sign off the final plans, and not need a copy of the approved plans.

Dennis M. Cawley

NOTE TO PLAN COMMISSION -

THESE RECOMMENDED CONDITIONS SHOULD
REPLACE CONDITIONS # 22-23 IN THE
JULY 6, 2009 "REPORT TO THE PLAN COMMISSION"