



# CITY OF MADISON FIRE DEPARTMENT

## Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295  
Phone: 608-266-4484 ♦ FAX: 608-267-1153

DATE: 6/13/08  
TO: Plan Commission  
FROM: Edwin J. Ruckriegel, Fire Marshal  
SUBJECT: **702 N. Midvale Blvd.**

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

**MAJOR OR NON-STANDARD REVIEW COMMENTS** (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

None

## **GENERAL OR STANDARD REVIEW COMMENTS**

In addition, we offer the following General or Standard Review Comments:

1. Provide fire apparatus access as required by Comm 62.0509 and MGO 34.19, as follows:
  - a. The site plans shall clearly identify the location of all fire lanes.
  - b. A dead-end fire lane that is longer than 150-feet shall terminate in a turnaround. Provide an approved turnaround (cul-de-sac, 45 degree wye, 90 degree tee) at the end of a fire lane that is more than 150-feet in length. One length shown over 150'.
2. All portions of the exterior walls of newly constructed public buildings and places of employment and open storage of combustible materials shall be within 500-feet of at least TWO fire hydrants. Distances are measured along the path **traveled by the fire truck as the hose lays off the truck**. See MGO 34.20 for additional information and show minimum 2 hydrants on site plan.

Please contact Scott Strassburg, New Construction Inspector at 608-261-9843 if you have questions regarding the above items.

cc: Bill Sullivan