



CITY OF MADISON FIRE DEPARTMENT

Fire Prevention Division

325 W. Johnson St., Madison, WI 53703-2295
Phone: 608-266-4484 ♦ FAX: 608-267-1153

DATE: 10/25/05
TO: Plan Commission
FROM: Edwin J. Ruckriegel, Fire Marshal
SUBJECT: **7502 West Towne Way**

The City of Madison Fire Department (MFD) has reviewed the subject development and has the following comments:

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. No comments.

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

2. All portions of the exterior walls of newly constructed public buildings and places of employment and open storage of combustible materials shall be within 500-feet of at least TWO fire hydrants. Distances are measured along the path **traveled by the fire truck as the hose lays off the truck**. See MGO 34.20 for additional information.
3. Provide an additional fire hydrant on the site plans; see MGO 34.20 for additional information. A minimum of 2 shall be shown.
4. Provide fire apparatus access as required by Comm 62.0509 and MGO 34.19, as follows:
 - a. The site plans shall clearly identify the location of all fire lanes.

Please contact John Lippitt, MFD Fire Protection Engineer, at 608-261-9658 if you have questions regarding the above items.

cc: John Lippitt