



Traffic Engineering Division

David C. Dryer, City Traffic Engineer

Madison Municipal Building
215 Martin Luther King, Jr. Boulevard
P.O. Box 2986
Madison, Wisconsin 53701-2986
PH 608/266-4761
TTY 608/267-9623
FAX 608/267-1158

May 4, 2006

TO: Plan Commission

FROM: David C. Dryer, P.E., City Traffic Engineer

SUBJECT: **1701 Thierer Road –Conditional Use – Construct New 8000 Sq. Ft. Retail**

The City Traffic Engineering Division has reviewed the subject development and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

2. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.
3. A "Stop" sign shall be installed at a height of seven (7) feet at all driveway approaches. All signs at the approaches shall be installed behind the property line. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
4. The applicant should show the dimensions for proposed and existing parking stalls' items A, B, C, D, E, and F, and for ninety-degree angle parking width and backing up, according to Figures II "Medium and Large Vehicles" parking design standards in Section 10.08(6)(b) 2.
5. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact John Leach, City Traffic Engineering at 267-8755 if you have questions regarding the above items:

Contact Person: John Bieno
Fax: 257-1092
Email: jjbienotjkdesignbuild.com

DCD:DJM:dm