



Traffic Engineering and Parking Divisions

David C. Dryer, P.E., City Traffic Engineer and Parking Manager

Suite 100
215 Martin Luther King, Jr. Boulevard
P.O. Box 2986
Madison, Wisconsin 53701-2986
PH 608 266 4761
TTY 866-704-2315
FAX 608 267 1158

March 8, 2007

TO: Plan Commission

FROM: The applicant shall show the dimensions for proposed and existing parking stalls' items A, B, C, D, E, F, and degree of angle parking width and backing up, according to Figures II "Medium and Large Vehicles" parking design standards in Section 10.08(6)(b) 2. Signs and planting areas are to be excluded from the rectangular stall areas including the two (2) feet of vehicle overhang. The two (2) feet of vehicle overhang shall be shown on the plan and dimensioned.

David C. Dryer, P.E., City Traffic Engineer and Parking Manager

SUBJECT: 444 Grand Canyon Drive – Conditional Use – Outdoor Eating Area

The City Traffic Engineering Division has reviewed the subject development and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None

PEDESTRIAN AND BICYCLE TRANSPORTATION REVIEW COMMENTS

2. None

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

3. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, all pavement markings, building placement, and stalls), signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.
4. A "Stop" sign shall be installed at a height of seven (7) feet at driveway approaches. All signs at the approaches shall be installed behind the property line. All directional/regulatory

signage and pavement markings on the site shall be shown and noted on the plan.

5. The applicant shall show the dimensions for proposed and existing parking stalls' items A, B, C, D, E, F, and degree of angle parking width and backing up, according to Figures II "Medium and Large Vehicles" parking design standards in Section 10.08(6)(b) 2. Signs and planting areas are to be excluded from the rectangular stall areas including the two (2) feet of vehicle overhang. The two (2) feet of vehicle overhang shall be shown on the plan and dimensioned.
6. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact John Leach, City Traffic Engineering at 267-8755 if you have questions regarding the above items:

Contact Person: Jeremy Cynkar
Fax: 268-1498
Email: Jeremy@destreearchitects.com

DCD: DJM: dm