



Traffic Engineering and Parking Divisions

David C. Dryer, P.E., City Traffic Engineer and Parking Manager

Suite 100
215 Martin Luther King, Jr. Boulevard
P.O. Box 2986
Madison, Wisconsin 53701-2986
PH 608 266 4761
TTY 866-704-2315
FAX 608 267 1158

September 14, 2006

TO: Plan Commission

FROM: David C. Dryer, P.E., City Traffic Engineer and Parking Manager

SUBJECT: **5002 Siggelkow Road – Conditional Use – 56 Unit Residential Development**

The City Traffic Engineering Division has reviewed the subject development and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

2. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), signage, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.
3. A "Stop" sign shall be installed at a height of seven (7) feet at the driveway approach. *All signs at the approach and shall be installed behind the property line.* All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
4. The applicant shall show the dimensions for all proposed parking garages and stalls' items B, C, E, F, and degree of angle parking width and backing up, according to Figures II "Medium and Large Vehicles" parking design standards in Section 10.08(6)(b) 2. Signs and planting areas are to be excluded from the rectangular stall areas including the two (2) feet of vehicle overhang. The two (2) feet of vehicle overhang shall be shown on the plan and dimensioned.
5. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact John Leach, City Traffic Engineering at 267-8755 if you have questions regarding the above items:

Contact Person: Chad Obright
Fax: 608-276-7880
Email: cobright1@charter.net

DCD: DJM: dm