



Traffic Engineering and Parking Divisions

David C. Dryer, P.E., City Traffic Engineer and Parking Manager

Suite 100
215 Martin Luther King, Jr. Boulevard
P.O. Box 2986
Madison, Wisconsin 53701-2986
PH 608 266 4761
TTY 866-704-2315
FAX 608 267 1158

November 8, 2007

TO: Plan Commission

FROM: David C. Dryer, P.E., City Traffic Engineer and Parking Manager

SUBJECT: **639 Pleasant View Drive – Rezoning – PUD (GDP-SIP) to Amended PUD (SIP) - 124 Unit Apartments**

The City Traffic Engineering Division has reviewed the subject development and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None

PEDESTRIAN AND BICYCLE TRANSPORTATION REVIEW COMMENTS

2. The applicant shall submit plans for the sidewalk and landscaping from Pleasant View Road to Shawn Trail as approved with the approved PUD.

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

3. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.
4. All existing driveway approaches on which are to be abandoned shall be removed and replaced with terrace or curb and gutter and noted on the plan.
5. The intersection shall be so designed so as not to violate the City's sight-triangle preservations requirement which states that on a corner lot no structure, screening, or

embankment of any kind shall be erected, placed, maintained or grown between the heights of 30 inches and 10 feet above the curb level or its equivalent within the triangle space formed by the two intersecting street lines or their projections and a line joining points on such street lines located a minimum of 25 feet from the street intersection in order to provide adequate vehicular vision clearance.

6. The applicant shall dimension the 32 unit buildings' underground parking areas for stalls and backing up according to Figures II of the ordinance using the 9' or wider stall for the commercial/retail area. The "One Size Fits All" stall shall be used for the residential parking area only, which is a stall 8'-9" in width by 17'-0" in length with a 23'-0" backup. Aisles, ramps, columns, offices or work areas are to be excluded from these rectangular areas, when designing underground parking areas.
7. The Developer shall post a deposit and reimburse the City for all costs associated with any modifications to Traffic Signals, Street Lighting, Signing and Pavement Marking, and conduit and handholes, including labor, engineering and materials for both temporary and permanent installations.
8. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact John Leach, City Traffic Engineering at 267-8755 if you have questions regarding the above items:

Contact Person: Patrick McGowan
Fax: 608-663-5151
Email: pmcgowan@hrownhousedesigns.com

DCD: DJM: dm