



Traffic Engineering and Parking Divisions

David C. Dryer, P.E., City Traffic Engineer and Parking Manager

Suite 100
215 Martin Luther King, Jr. Boulevard
P.O. Box 2986
Madison, Wisconsin 53701-2986
PH 608 266 4761
TTY 866-704-2315
FAX 608 267 1158

March 13, 2008

TO: Plan Commission
FROM: David C. Dryer, P.E., City Traffic Engineer and Parking Manager
SUBJECT: **801 Atlas Avenue – Conditional Use – Auto Sales**

The City Traffic Engineering Division has reviewed the subject development and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project.)

1. None

PEDESTRIAN AND BICYCLE TRANSPORTATION REVIEW COMMENTS

2. The applicant shall indicate the type of bicycle racks to be installed and location by the entrances outside the building.

GENERAL OR STANDARD REVIEW COMMENTS

In addition, we offer the following General or Standard Review Comments:

3. When the applicant submits final plans for approval, the applicant shall show the following: items in the terrace as existing (e.g., signs and street light poles), type of surfaces, existing property lines, addresses, one contiguous plan (showing all easements, all pavement markings, building placement, and stalls), signage, percent of slope, vehicle routes, dimensions of radii, aisles, driveways, stalls including the two (2) feet overhang, and a scaled drawing at 1" = 20'.
4. A "Stop" sign shall be installed at a height of seven (7) feet at the driveway approaches. All signs at the approaches shall be installed behind the property line. All directional/regulatory signage and pavement markings on the site shall be shown and noted on the plan.
5. The applicant shall modify and dimension existing and proposed parking stalls and backing

up according to Figures II of the ordinance using the 9' or wider stall for the commercial/retail area.

6. The parking facility shall be modified to provide for adequate internal circulation for vehicles. This can be accommodated by eliminating a parking stall at the dead ends. The eliminated stall shall be modified to provide a turn around area ten (10) to twelve (12) feet in width and signed "No Parking Anytime."
7. Public signing and marking related to the development may be required by the City Traffic Engineer for which the developer shall be financially responsible.

Please contact John Leach, City Traffic Engineering at 267-8755 if you have questions regarding the above items:

Contact Person: Lee Loveall Jr
Fax: 608-884-7228
Email: thefnpainter@aol.com

DCD: DJM: dm