

**CITY OF MADISON
MADISON WATER UTILITY
119 East Olin Avenue
266-4651**

MEMORANDUM

Date: June 18, 2007

To: The Plan Commission
From: Dennis M. Cawley, Engineer 4 - Water Utility
Subject: DEMOLITION - 2501 West Beltline Highway

The Madison Water Utility has reviewed this demolition request and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS

Each lot of record shall have a separate water service lateral connection to a public water main.

GENERAL OR STANDARD REVIEW COMMENTS

The Madison Water Utility shall be notified to remove the water meters prior to demolition.

The Water Utility will not need to sign off the final plans, and will not need a copy of the approved plans.

Dennis M. Cawley