

**CITY OF MADISON
MADISON WATER UTILITY
119 East Olin Avenue
266-4651**

MEMORANDUM

Date: December 7, 2005

To: The Plan Commission
From: Dennis M. Cawley, Engineer IV - Water Utility
Subject: REZONING – 33 South Broom Street

Madison Water Utility has reviewed this rezoning and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS

None

GENERAL OR STANDARD REVIEW COMMENTS

The note on the Utility Plan Sheet concerning the water service connection shall be changed to indicate that the existing water main in S. Broom St. is a 4" water main.

The Water Utility will not need to sign off the final plans, and will not need a copy of the approved plans.

Dennis M. Cawley