

**CITY OF MADISON  
MADISON WATER UTILITY  
119 East Olin Avenue  
266-4651**

**MEMORANDUM**

**Date:** August 10, 2006

**To:** The Plan Commission  
**From:** Dennis M. Cawley, Engineer 4 - Water Utility  
**Subject:** DEMOLITION – 5901 Odana Road

The Madison Water Utility has reviewed this demolition request and has the following comments.

**MAJOR OR NON-STANDARD REVIEW COMMENTS**

None

**GENERAL OR STANDARD REVIEW COMMENTS**

The Madison Water Utility shall be notified to remove the water meters prior to demolition. The proposed water service as shown on the plans is required to be a public water main by State Administrative Code because it is a looped system. If the owner decides not to have a public water main on the property, then the proposed water service system shall be redesigned.

The Water Utility will not need to sign off the final plans, and will not need a copy of the approved plans.

Dennis M. Cawley