

**CITY OF MADISON
MADISON WATER UTILITY
119 East Olin Avenue
266-4651**

MEMORANDUM

Date: May 24, 2006

To: The Plan Commission
From: Dennis M. Cawley, Engineer IV - Water Utility
Subject: REZONING – 5901 Sharpsburg Drive

Madison Water Utility has reviewed this rezoning and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS

The Utility Plan sheet shows a water lateral extension to the east to potentially serve a different parcel of land. Madison Water Utility Rules and Regulations require that each parcel of land have a separate water service lateral connection to a public water main.

GENERAL OR STANDARD REVIEW COMMENTS

None

The Water Utility will not need to sign off the final plans, nor need a copy of the approved plans.

Dennis M. Cawley