

**CITY OF MADISON
MADISON WATER UTILITY
119 East Olin Avenue
266-4651**

MEMORANDUM

Date: October 25, 2006

To: The Plan Commission
From: Dennis M. Cawley, Engineer 4 - Water Utility
Subject: DEMOLITION / REZONING – 702 N. Midvale Boulevard

The Madison Water Utility has reviewed this demolition / rezoning request and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS

The proposed private water main system shall be installed with check valves in accordance with State Administrative Code NR 811.08(1)(b). The proposed private water main along University Avenue shall be installed on private property not in the public right-of-way.

GENERAL OR STANDARD REVIEW COMMENTS

The Madison Water Utility shall be notified to remove the water meter prior to demolition.

The Water Utility will need to sign off the final plans, but will not need a copy of the approved plans.

Dennis M. Cawley