

**CITY OF MADISON
MADISON WATER UTILITY
119 E. Olin Avenue
266-4651**

MEMORANDUM

Date: May 14, 2007

To: The Plan Commission
From: Dennis M. Cawley, Engineer IV - Water Utility
Subject: LOT DIVISION – 702 North Midvale Boulevard

The Madison Water Utility has reviewed this lot division and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS

None

GENERAL OR STANDARD REVIEW COMMENTS

None

The Water Utility will not need to sign off the final plans, but will need a copy of the approved plans.

Dennis M. Cawley