

**CITY OF MADISON  
MADISON WATER UTILITY  
119 East Olin Avenue  
266-4651**

**MEMORANDUM**

**Date:** May 14, 2007

**To:** The Plan Commission  
**From:** Dennis M. Cawley, Engineer 4 - Water Utility  
**Subject:** PRELIMINARY/FINAL PLAT – Hilldale Phase 2

The Madison Water Utility has reviewed this preliminary/final plat and has the following comments.

**MAJOR OR NON-STANDARD REVIEW COMMENTS**

None

**GENERAL OR STANDARD REVIEW COMMENTS**

Madison Water Utility rules and regulations require that each lot have a separate water service lateral connected to a public water main. The developer shall provide a plan to the Madison Water Utility showing the proposed water service laterals for each lot.

The Water Utility will not need to sign off the final plans, but will need a copy of the approved plans.

Dennis M. Cawley