

**CITY OF MADISON
MADISON WATER UTILITY
119 E. Olin Avenue
266-4651**

MEMORANDUM

Date: August 15, 2007

To: The Plan Commission
From: Dennis M. Cawley, Engineer IV - Water Utility
Subject: LOT DIVISION – 8001 Raymond Road

The Madison Water Utility has reviewed this lot division and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS

None

GENERAL OR STANDARD REVIEW COMMENTS

There is no existing water main adjacent to Lot 2. Additional public water main easement shall be dedicated across lot 1 to serve lot 2. Water mains and water service laterals shall be installed by standard City of Madison Subdivision Contract.

The Water Utility will not need to sign off the final plans, but will need a copy of the approved plans.

Dennis M. Cawley