

**CITY OF MADISON
MADISON WATER UTILITY
119 East Olin Avenue
266-4651**

MEMORANDUM

Date: April 10, 2006

To: The Plan Commission
From: Dennis M. Cawley, Engineer IV - Water Utility
Subject: REZONING – 8240 Mineral Point Road

Madison Water Utility has reviewed this rezoning and has the following comments.

MAJOR OR NON-STANDARD REVIEW COMMENTS

The proposed water service design is in violation of the Madison Water Utility rules and regulations, which require a separate water service lateral connection to a public water main for each lot of record.

GENERAL OR STANDARD REVIEW COMMENTS

None

The Water Utility will need to sign off the final plans, but will not need a copy of the approved plans.

Dennis M. Cawley