

**CITY OF MADISON
INTERDEPARTMENTAL
CORRESPONDENCE**

Date: November 16, 2006

To: Plan Commission

From: Kathy Voeck, Assistant Zoning Administrator

Subject: 1405 Emil St, Conditional Use

Present Zoning District: M-1

Proposed Use: Outdoor eating area for Licari's Bar and Grill, (Capacity including outside is 80 persons)

Conditional Use: 28.10(4)(d)9 Outdoor eating areas are a conditional use

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project). **NONE.**

GENERAL OR STANDARD REVIEW COMMENTS

1. Note: The capacity of the inside and outside eating area is limited to 80 persons total per the building code and for the parking provided.
2. Meet all applicable State accessible requirements, including but not limited to:
 - a. Provide a minimum of **one** accessible stall striped per State requirements. A minimum of one of the stalls shall be a van accessible stall 8' wide with an 8' striped out area adjacent.
 - b. **Show signage at the head of the stall. Accessible signs shall be a minimum of 60" between the bottom of the sign and the ground.**
3. Provide **two** bike parking stalls in a safe and convenient location on an impervious surface to be shown on the final plan. The lockable enclosed lockers or racks or equivalent structures in or upon which the bicycle may be locked by the user shall be securely anchored to the ground or building to prevent the lockers or racks from being removed from the location. NOTE: A bike-parking stall is two feet by six feet with a five-foot access area. Structures that require a user-supplied locking device shall be designed to accommodate U-shaped locking devices.

1405 Emil St.

4. Parking lot plans with greater than twenty (20) stalls, landscape plans must be stamped by a registered landscape architect. Provide a landscape worksheet with the final plans that shows that the landscaping provided meets the point and required tree ordinances. In order to count toward required points, the landscaping shall be within 15' and 20' of the parking lot depending on the type of landscape element. (Note: The required trees do not count toward the landscape point total.) **Planting islands shall consist of at least 75% vegetative cover, including trees, shrubs, ground cover, and/or grass. Up to 25% of the island surface may be brick pavers, mulch or other non-vegetative cover.** All plant materials in islands shall be protected from vehicles by concrete curbs.

ZONING CRITERIA

Bulk Requirements	Required	Proposed
Lot Area	6,000 sq. ft.	20,050 sq. ft.
Lot width	50'	100'
Usable open space	n/a	n/a
Front yard	0'	adequate
Side yards	0'	adequate
Rear yard	10'	adequate
Floor area ratio	2.0	less than 1.0
Building height	---	1 story

Site Design	Required	Proposed
Number parking stalls	24 (total capacity 80 persons)	24
Accessible stalls	1	(2)
Loading	n/a	n/a
Number bike parking stalls	2	(3)
Landscaping	Yes	(4)
Lighting	No	existing

Other Critical Zoning Items	
Urban Design	No
Flood plain	No
Barrier free (ILHR 69)	Yes

With the above conditions, the proposed project **does** comply with all of the above requirements.