

**CITY OF MADISON
INTERDEPARTMENTAL
CORRESPONDENCE**

Date: February 21, 2007

To: Plan Commission

From: Kathy Voeck, Assistant Zoning Administrator

Subject: 444 Grand Canyon Dr.

Present Zoning District: C3L

Proposed Use: Outdoor eating area for Park Towne Lanes

Conditional Use: 28.09(3)(d)32. Outdoor eating areas are a conditional use.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project). **NONE.**

GENERAL OR STANDARD REVIEW COMMENTS

1. Meet all applicable State accessible requirements, including but not limited to:
 - a. Provide a minimum of **7** accessible stalls striped per State requirements. A minimum of one of the stalls shall be a van accessible stall 8' wide with an 8' striped out area adjacent. The rest of the accessible stalls shall have a 5' striped out area adjacent.
 - b. Show signage at the head of the stalls. Accessible signs shall be a minimum of 60" between the bottom of the sign and the ground.
 - c. Show the accessible path from the stalls to the building. The stalls shall be as near the accessible entrance as possible. Show ramps, curbs, or wheel stops where required.

2. Provide **twenty** bike parking stalls in a safe and convenient location on an impervious surface to be shown on the final plan. The lockable enclosed lockers or racks or equivalent structures in or upon which the bicycle may be locked by the user shall be securely anchored to the ground or building to prevent the lockers or racks from being removed from the location. NOTE: A bike-parking stall is two feet by six feet with a five-foot access area. Structures that require a user-supplied locking device shall be designed to accommodate U-shaped locking devices.

444 Grand Canyon Dr.

3. Parking lot plans with greater than twenty (20) stalls, landscape plans must be stamped by a registered landscape architect. Provide a landscape worksheet with the final plans that shows that the landscaping provided meets the point and required tree ordinances. In order to count toward required points, the landscaping shall be within 15' and 20' of the parking lot depending on the type of landscape element. (Note: The required trees do not count toward the landscape point total.) Planting islands shall consist of at least 75% vegetative cover, including trees, shrubs, ground cover, and/or grass. Up to 25% of the island surface may be brick pavers, mulch or other non-vegetative cover. All plant materials in islands shall be protected from vehicles by concrete curbs.

ZONING CRITERIA

Bulk Requirements	Required	Proposed
Lot Area	6,000 sq. ft.	138,730 sq. ft.
Lot width	50'	300'
Usable open space	n/a	n/a
Front yard	0'	adequate
Side yards	0'	adequate
Rear yard	10'	n/a
Floor area ratio	3.0	less than 1.0
Building height	---	1 story

Site Design	Required	Proposed
Number parking stalls	As shown	203
Accessible stalls	7	(1)
Loading	Existing	Existing
Number bike parking stalls	20	(2)
Landscaping	Yes	(3)
Lighting	No	Exsiting

Other Critical Zoning Items	
Urban Design	No
Flood plain	No
Utility easements	None shown
Barrier free (ILHR 69)	

With the above conditions, the proposed project **does** comply with all of the above requirements.