

**CITY OF MADISON  
INTERDEPARTMENTAL  
CORRESPONDENCE**

**Date:** February 19, 2007

**To:** Plan Commission  
**From:** Kathy Voeck, Assistant Zoning Administrator  
**Subject:** **801 Redan Dr, CU**

---

**Present Zoning District:** Conservancy

**Proposed Use:** Linden Park Elementary School

**Conditional Use:** 28.07(2)(c)15. Elementary schools are a conditional use.

MAJOR OR NON-STANDARD REVIEW COMMENTS (Comments which are special to the project and/or may require additional work beyond a standard, more routine project). **NONE.**

GENERAL OR STANDARD REVIEW COMMENTS

1. Provide **42** bike parking stalls in a safe and convenient location on an impervious surface to be shown on the final plan. The lockable enclosed lockers or racks or equivalent structures in or upon which the bicycle may be locked by the user shall be securely anchored to the ground or building to prevent the lockers or racks from being removed from the location. NOTE: A bike-parking stall is two feet by six feet with a five-foot access area. Structures that require a user-supplied locking device shall be designed to accommodate U-shaped locking devices.
2. Parking lot plans with greater than twenty (20) stalls, landscape plans must be stamped by a registered landscape architect. Provide a landscape worksheet with the final plans that shows that the landscaping provided meets the point and required tree ordinances. In order to count toward required points, the landscaping shall be within 15' and 20' of the parking lot depending on the type of landscape element. (Note: The required trees do not count toward the landscape point total.) Planting islands shall consist of at least 75% vegetative cover, including trees, shrubs, ground cover, and/or grass. Up to 25% of the island surface may be brick pavers, mulch or other non-vegetative cover. All plant materials in islands shall be protected from vehicles by concrete curbs.
3. Lighting is not required. However, if it is provided, it must comply with City of Madison outdoor lighting standards. (See parking lot packet). Lighting will be limited to .08 watts per square foot.

**ZONING CRITERIA**

<b>Bulk Requirements</b>	<b>Required</b>	<b>Proposed</b>
Lot Area	10 acres	8.32 acres (existing lot)
Lot width	500'	507.43'
Usable open space	n/a	n/a
Front yard	60'	30' (pending P.C. approval)
Side yards	80'	30' & 110' (pending PC app)
Rear yard	100'	adequate
Floor area ratio	n/a	n/a
Building height	2 stories/35'	2 stories/35' av. mean

<b>Site Design</b>	<b>Required</b>	<b>Proposed</b>
Number parking stalls	45	117
Accessible stalls	5	5
Loading	1 (10' x 35') area	provided
Number bike parking stalls	42	(1)
Landscaping	Yes	(2)
Lighting	No	(3)

<b>Other Critical Zoning Items</b>	
Urban Design	Yes
Historic District	No
Landmark building	No
Flood plain	No
Utility easements	No
Water front development	No
Adjacent to park	No
Barrier free (ILHR 69)	Yes

With the above conditions, the proposed project **does** comply with all of the above requirements.