



## **Madison Water Utility**

Tom Heikkinen – General Manager  
Alan L. Larson P.E. – Principal Engineer

119 E. Olin Avenue  
Madison, Wisconsin 53713  
Telephone: 608 266-4653  
FAX: 608 266-4426  
email: allarson@cityofmadison.com

# **Public Meeting Notes**

## **Arbor Hills Supplemental Fire Flow Supply**

Date: Thursday, September 10, 2009 @ 6:30 p.m.  
Location: Zimbrick Buick Community Room  
Attendance: 11

Subject: **Public Meeting to Discuss Alternative Evaluation Report**

The Utility Project Manager, Al Larson, led the meeting. Mr. Larson presented the project details and alternatives considered. Copies of the project evaluation report were available to attendees.

The recommended alternate is to construct a 2,000 gallon per minute pump station in the vicinity of the proposed Cannonball Trail. No opposition to the recommended alternative was voiced at the meeting.

Questions raised by attendees covered several topics:

1. Function of the pump station? Move water from Well 18 to Arbor Hill and Zone 7.
2. How large will the building be? Approximately 1,000 square feet
3. How much parking is required? One possibly two spaces
4. How often would it be visited? Once per day
5. What will the building look like? We will work with the CAP and the neighborhood to construct a facility that fits in.
6. How large a site would be required? Probably less than 10,000 square feet

Discussion on several potential sites along the Cannonball Trail indicated that there is a good possibility of finding a suitable site during the next phase. The general feeling was to stay away from the park and the greenway. It was stated that the greenway is going to be used for a storm water infiltration project and would therefore not be suitable for the pump station.

Next Steps: A public hearing will be set up before the Water Board meeting on Tuesday September 29<sup>th</sup> @ 4:30 p.m. At that meeting the Board will be presented with the recommendation to construct a pump station. If the Board accepts the recommendation, the project will move to site selection.