

# Appendix B

Contract 8359

Burr Jones Park – Electrical System  
Specifications

1 **SECTION 26 00 00 - ELECTRICAL**

2  
3  
4 **PART 1 - GENERAL**

5  
6 **1.01 DESCRIPTION**

7  
8 A. Work Included: Provide complete electrical service and distribution system with equipment and  
9 materials where shown on the Drawings, as specified herein, and as needed for a complete and  
10 proper installation including, but not necessarily limited to:

- 11  
12 1. Underground Electric Service (200-amp, 3-phase, 277/480Y-volt), service disconnect -  
13 meter cabinet with service ground, distribution panel with main circuit breaker and branch  
14 circuit breakers;  
15 2. Transformers;  
16 3. Branch circuit wiring for lighting and equipment;  
17 4. Hangers, anchor sleeves, hand hole pull boxes, supports, and other related electrical  
18 materials;  
19 5. Other items and services required to complete the electrical systems.

20  
21 B. Related Work:

- 22  
23 1. Documents affecting work of this Section include, but are not necessarily limited to,  
24 General Conditions, Supplementary Conditions, and Sections in Division 1 of these  
25 Specifications;  
26 2. Equipment structural supports, enclosures and pads, etc.;  
27 3. All line voltage control wiring and starter interlocks, where specified;  
28 4. Final lighting equipment electrical connections.

29  
30 C. Work of Other Sections:

- 31  
32 1. See Appendix C for Athletic Field Lighting System.

33  
34 **1.02 GENERAL PROVISIONS**

35  
36 A. Everything essential for the completion of the work implied to be covered by these Specifications  
37 to make the system ready for normal and proper operation must be furnished and installed by this  
38 Contractor. Accordingly, any omission from either the plans or the Specifications, or both, of  
39 details necessary for the proper installation and operation of the system shall not relieve this  
40 Contractor from furnishing such detail in full and proper manner.

41  
42 B. In addition to the electrical plans, see General Plans of the building, as all electrical work  
43 appearing on the latter plans will be part of this contract unless especially specified to be done by  
44 other contractors, as well as, the said work detailed on the electrical plans.

45  
46 **1.03 QUALITY ASSURANCE**

47  
48 A. Use adequate numbers of skilled workmen who are thoroughly trained and experienced in the  
49 necessary crafts and who are completely familiar with the specified requirements and methods  
50 needed for proper performance of the work of this Section.

51  
52 B. Without additional cost to the Owner, provide such other labor and materials as required to  
53 complete the work of this Section in accordance with the requirements of governmental agencies  
54 having jurisdiction, regardless of whether such materials and associated labor are called for  
55 elsewhere in these Contract Documents.

56  
57 C. Reference Standard: The following standards are imposed, as applicable to the work:  
58

1	ASTM	American Society of Testing and Materials
2	NEC	National Electrical Code
3	NEMA	National Electrical Manufacturers Association
4	NFPA	National Fire Protection Association
5	UL	Underwriters Laboratories

7 **1.04 CODES AND PERMITS**

- 9 A. The Contractor must comply with national, state of Wisconsin and city of Kenosha building and  
10 electrical codes and other ordinances in force where the building is located as far as same apply  
11 to his work.
- 13 1. IBC 2015;  
14 2. IEEC 2015;  
15 3. NEC 2014;  
16 4. Wisconsin Electrical Code SPS sections.
- 18 B. He must secure permits from proper offices and pay fees as may be necessary for fulfilling the  
19 requirements of these Specifications.
- 21 C. One (1) copy of all permits must be furnished to the Owner.
- 23 D. Electric Service Fee: Electrical Contractor shall secure and pay all fees for new electrical service  
24 from electric utility, including temporary power services.

26 **1.05 COORDINATION**

- 28 A. Cooperate and coordinate with other trades to assure that all systems in the electrical work may  
29 be installed in the best arrangement. Coordinate as required with all other trades to share space  
30 in common areas and to provide the maximum of access to each system.
- 32 B. Arrange electrical work in neat, well-organized manner with piping and similar running parallel  
33 with primary lines of building construction.
- 35 C. Locate operating and control equipment properly to provide easy access, and install entire  
36 electrical systems with adequate access for operation and maintenance.
- 38 D. Give right-of-way to piping which must slope for drainage.

40 **1.06 ELECTRICAL PROVISIONS OF THE MECHANICAL WORK**

- 42 A. Line Voltage Wiring: The Electrical Contractor shall make all line voltage (100 volts and greater)  
43 electrical wiring, final connections and motor wiring for Mechanical equipment.
- 45 B. Control Wiring: Low-voltage (less than 100 volts) control wiring in conjunction with Mechanical  
46 work shall be by the Mechanical Contractor in strict accordance with the applicable sections of  
47 the Electrical Specifications.
- 49 C. Motors, Starters, and Disconnects: All motors starter and disconnects shall be provided by the  
50 Electrical Contractor, unless provided with the equipment or indicated otherwise.
- 52 1. Mechanical Contractors shall furnish list of and location of all Mechanical equipment and  
53 requirements for electrical connections, along with wiring diagrams.

55 **1.07 FLOOR, WALL, ROOF AND CEILING OPENINGS**

- 1 A. The General Contractor will be required to leave openings in new construction ceiling, floors,  
2 walls, roof, partitions, etc., as required to install the Electrical work specified or shown on the  
3 Drawings. The Electrical Contractor is responsible for correct size and location of openings.  
4  
5 B. Provisions for openings, holes and clearances through new construction walls, floors, ceilings  
6 and partitions are to be made in advance of construction of such parts of the building.  
7  
8 C. The Electrical Contractor shall set sleeves and anchors for all equipment, etc., and shall provide  
9 watertight seals on pipes through exterior walls, floors and roof locations, and where noted on the  
10 Drawings.  
11

## 12 **1.08 CUTTING AND PATCHING**

- 13  
14 A. General: Refer to Division 1 General Requirements.  
15  
16 B. Perform all cutting and patching required for complete installation of the Electrical systems,  
17 unless specifically noted otherwise. Provide all materials required for patching unless otherwise  
18 noted.  
19  
20 1. All cutting and patching necessary of structural members to install any Electrical work  
21 shall not be done without permission, and then only carefully done under the direction of  
22 the Architect and General Contractor.  
23

## 24 **1.09 TRENCHING AND BACKFILLING**

- 25  
26 A. Comply with pertinent provisions of Division 1.  
27  
28 B. Perform trenching and backfilling associated with the work of this Section in strict accordance  
29 with the provisions of Division 2 of the Specifications.  
30

## 31 **1.10 SUBMITTALS**

- 32  
33 A. Comply with pertinent provisions of Division 1.  
34  
35 B. Shop Drawing Submittals: Submit six (6) copies of shop drawings to the Architect for approval,  
36 with complete detail for all equipment, materials, etc., to be furnished and installed for this project  
37 as follows:  
38  
39 1. Electric Service Equipment;  
40 2. Distribution Panelboards;  
41 3. Transformers;  
42 4. Conductors and Cables;  
43 5. Raceways, Boxes and Supports;  
44 6. Hand Holds;  
45 7. Miscellaneous Electrical Devices.  
46  
47 C. Shop Drawings:  
48  
49 1. The Electrical Contractor will be held responsible for correction of work deemed  
50 necessary by the Engineer due to proceeding with the electrical work without approved  
51 shop drawings that have the Architect/Engineers final approval.  
52 2. Shop drawings shall include data on physical dimensions, gauges, materials of  
53 construction and capacities. Incomplete drawings will be disapproved.  
54 3. This Contractor will be responsible for all figures, quantities and dimensions shown on  
55 the shop drawings.  
56 4. Approval of shop drawings describing equipment that cannot fit in the space allotted does  
57 not relieve this Contractor from responsibility of resubmitting equipment that will meet the  
58 space requirements.

1  
2 D. O & M Manual: Upon completion of this portion of the Work, and as a condition of its  
3 acceptance, deliver to the Architect two (2) copies of an operation and maintenance manual  
4 compiled in accordance with the provisions of Division 1 of these Specifications. Include the  
5 following within the bound O&M manual:  
6

- 7 1. Copy of the approved Record Documents for this portion of the Work;
- 8 2. Copies of all warranties and guaranties.
- 9 3. As-built drawings.

10  
11 E. As-built Drawings: Record installation as-built on a set of blueline prints during construction.  
12 Plan shall represent actual locations, materials and circuiting of equipment installed.  
13

#### 14 1.11 PRODUCT HANDLING

15  
16 A. Comply with pertinent provisions of Division 1.  
17

#### 18 1.12 WARRANTY

19  
20 A. In addition to standard one year warranty on all labor and materials, provide an additional  
21 warranty on ballasts for all new fluorescent and HID lighting fixtures as specified.  
22

#### 23 1.13 HOUSEKEEPING AND CLEAN-UP

24  
25 A. Periodically as work progresses and/or as directed by the Architect, the Contractor shall remove  
26 waste materials from the building and leave the area of the workroom clean. Upon completion of  
27 work remove all tools, scaffolding, broken and waste materials, etc., from the site.  
28

#### 29 1.14 TEMPORARY SERVICES

- 30  
31 A. This Contractor shall provide temporary lighting and power as required throughout the  
32 construction period.  
33  
34 B. Arrange for temporary electrical utility with local electrical utility. Electrical Contractor shall pay all  
35 temporary electrical service and usage fees.  
36  
37

### 38 PART 2 - PRODUCTS

#### 39 2.01 GENERAL

40  
41  
42 A. Provide only materials that are new, of the type and quality specified. Where Underwriters'  
43 Laboratories, Inc. has established standards for such materials, provide only materials bearing  
44 the UL label.  
45

#### 46 2.02 SERVICE ENTRANCES AND METERING

- 47  
48 A. New Service: Provide new underground 200A, 277/480Y volt, 3-phase, 4-wire electric service  
49 from pad-mounted transformer as required by the local electrical utility(MG&E) and as shown on  
50 Drawings.  
51  
52 B. Metering: Provide combination service disconnect with ground and metering socket cabinet for  
53 exterior mounting and related metering equipment per local electrical utility requirements(MG&E).  
54  
55 1. Utility approved metering equipment: Milbank U5787-O-200-CB  
56  
57 C. Main Switches: Provide a 200-amp main circuit breakers in the service metering cabinet with  
58 current limiting capabilities to meet utility AIC requirements.

1  
2 D. Service Distribution Panel (Panel 'A'):  
3

- 4 1. Provide 200-amp, 3-phase main distribution panel as indicated on plans complete with  
5 200-amp main circuit breaker rated for 35,000 AIC, branch circuit breakers, NEMA 3R  
6 enclosure, main service ground and solid neutral buss lugs and other components  
7 required for a complete installation.  
8

9 **2.03 GROUNDING SYSTEM**

- 10  
11 A. Ground all equipment, including switches, transformers, conduit systems, motors, and other  
12 apparatus, by conduit or conductor to cold water main and to independent electrode, using  
13 ground clamps manufactured by Burndy or T&B, and approved by the Engineer.  
14  
15 B. Provide new service grounding electrode system. Add ground rod grounding electrodes as  
16 required per NEC 250.50 for a common grounding electrode system.  
17  
18 C. Provide grounding conductor from service ground to solid ground buss bar at all distribution  
19 panelboards.  
20  
21 D. Provide grounding jumper from grounding electrode to metallic support posts.  
22  
23 E. Ground all motor and equipment connections with dedicated ground conductor.  
24

25 **2.04 IDENTIFICATION**

- 26  
27 A. Junction and pull boxes shall be stenciled utilizing a coded identification system. The following  
28 junction and pull boxes shall be identified using a coded system. Coding shall be submitted to  
29 Engineer for approval.  
30  
31 1. Controls - 120V;  
32 2. Power & Lighting - 277/480V.  
33  
34 B. Label circuit numbers for all accessible line voltage power distribution raceways and junction  
35 boxes.  
36  
37 C. Laminated Bakelite Plates: Engraved plastic nameplate shall be securely fastened to the  
38 following equipment. Size 1" x 4" with 3/8" high letters unless space available dictates differently.  
39  
40 1. Panelboards.  
41  
42 D. Typewritten Directory: Each panelboard shall be provided with a typewritten directory in a steel  
43 frame with plastic cover contained on the inside of panel door. These directories shall indicate  
44 load served and rooms served by each protective device in the respective panel.  
45  
46 E. Identify all conductors per NEC:  
47  
48 120/240V - Phase A - Black  
49 - Phase B - Red  
50 - Neutral - White  
51 - Ground - Green  
52  
53 277/480V - Phase A - Yellow  
54 - Phase B - Brown  
55 - Phase C - Orange  
56 - Neutral - Gray  
57 - Ground - Green with two yellow stripes  
58

1 **2.05 POWER DISTRIBUTION SYSTEM**

- 2
- 3 A. See plans for panelboard capacity, voltage ratings, and branch circuit breaker units.
- 4
- 5 B. All panelboards to be of the circuit breaker type with bolt-on circuit breakers. AIC rating as
- 6 scheduled on drawings.
- 7
- 8 C. Branch circuit breakers shall be thermal magnetic; quick-make and quick break. Multi-pole
- 9 breakers to have common trip. Handle ties of any sort not allowed.
- 10
- 11 D. Panelboards shall be Square 'D' type NF with bolt-on branch circuit breakers rated for 35,000
- 12 AIC.
- 13
- 14 1. Square 'D' is the only approved manufacturer for this project.
- 15
- 16 E. Each panel shall be provided with a typewritten directory mounted on inside of panel door and
- 17 covered with clear plastic. This directory shall indicate the load supplied by each branch circuit
- 18 breaker in panel. Room numbers shall be actual room numbers.
- 19
- 20 F. Each panelboard shall be securely attached to support structure with galvanized unistrut
- 21 supports.
- 22
- 23 G. All panelboards shall be equipped with an equipment grounding bar that is separate from the
- 24 solid neutral bar.
- 25

26 **2.06 TRANSFORMERS**

- 27
- 28 A. Furnish and install exterior rated single phase transformers as indicated on the electrical plans.
- 29
- 30 1. Square 'D' type 'T' series sealed transformers.
- 31 2. Primary voltage: 277-volt; Secondary voltage: 120-volt.
- 32 3. Rating: 1000 VA; 1-phase.
- 33 4. Secondary fuse block.
- 34 5. NEMA 3R enclosure with removable front.
- 35
- 36 B. Transformers shall be 115 degrees C temperature rise above 40 degrees C ambient. 115
- 37 degrees C rise transformers shall be capable of carrying a 15% continuous overload without
- 38 exceeding a 150 degrees C rise in a 40 degrees C ambient. All insulating materials to be in
- 39 accordance with NEMA ST20 standards for a 220 degrees C UL component recognized
- 40 insulation system.
- 41
- 42 C. Transformer coils shall be of the continuous wound construction and shall be impregnated with
- 43 non-hygroscopic, thermosetting varnish.
- 44
- 45 D. The core of the transformer shall be visibly grounded to the enclosure by means of a flexible
- 46 grounding conductor sized in accordance with applicable NEMA, IEEE, and ANSI standards.
- 47

48 **2.07 RACEWAY SYSTEM**

- 49
- 50 A. Steel Conduit. Galvanized or sheradized steel intermediate or rigid metal conduit, or electrical
- 51 metallic tubing (EMT) with steel set screw or compression ring type fittings.
- 52
- 53 1. Provide rigid galvanized steel conduits as all exterior exposed areas.
- 54 2. Where conduit is installed underground or in the floor slab, provide rigid galvanized steel
- 55 conduit, or PVC coated steel conduit is acceptable.
- 56 3. Provide liquid-tight flexible conduit in all exterior locations
- 57
- 58 B. Conduit:

- 1
- 2
- 3
- 4
- 5
- 6 C. Rigid Steel Conduit and Fittings:
- 7
- 8 1. Manufactured to ANSI C80.1 standards
- 9 2. Fittings: Threaded steel type as per ANSI/NEMA FB1
- 10
- 11 D. Rigid Non-Metallic Conduit: Schedule 40 PVC with solvent welded fittings.
- 12
- 13 1. Below grade installation only.
- 14 2. Encase in concrete below drives and roadways.
- 15
- 16 E. Liquid-Tight Flexible Conduit Fittings:
- 17
- 18 1. Conduit: Flexible metal conduit with PVC jacket.
- 19 2. Fittings as per ANSI/NEMA FB1.
- 20
- 21 F. Pull Boxes:
- 22
- 23 G. Electrical Hand Hold Splice Boxes:
- 24
- 25 1. Provide flush at grade splice boxes constructed of fiberglass polymer
- 26 concrete reinforced with removable access cover labeled "ELECTRIC" and stainless
- 27 steel cover fasteners. Cover shall be cast iron, bronze or fiberglass polymer UV rated.
- 28
- 29 1. MacLean Highline CHA132412-H(12"x21-1/2"x12"high) or approved equal.
- 30 2. Cover assembly shall be load tested per ANSI/SCTE 77 for 12,000 lbs.
- 31 3. Mount splice box on 6" compacted gravel base and pour 4" concrete collar(4" deep)
- 32 with reinforcing rod around top for protection.
- 33
- 34 H. Provide sleeves and chases where conduits pass through floors and walls.
- 35

## 36 2.08 CONDUCTORS

- 37
- 38 A. Wire and Cable (600 Volt): Provide 600 V insulated copper wire and cable, NEC standard, of
- 39 types specified below for different applications, with UL label, and color coded as required by
- 40 governmental agencies having jurisdiction. Use only copper wires and cables.
- 41
- 42 1. With conductors No. 4 and larger, provide insulating bushings.
- 43 2. Wire and cable shall be THHN or THWN.
- 44 3. Branch circuit wiring installed in wiring channels of continuous row-mounted fixtures shall
- 45 be provided. UL listed type RHH or other approved 90 degree C wires, rated at 600 V.
- 46 4. Wire No. 10 and smaller shall be solid or stranded wire; wire larger than No. 10 shall be
- 47 stranded wire.
- 48 5. Wire in conduits subjected to direct sunlight shall be THWN or RHWN.
- 49 6. Provide XHHW/CU wiring in underground exterior conduit.
- 50 7. Identify feeder neutrals with white tape or white paint.
- 51 8. All low-voltage wiring located in accessible areas shall be installed in metallic conduit.
- 52 9. Provide separate identified neutral conductor for emergency and exit lighting circuits.
- 53 10. All branch circuit conductors shall be connected by means of a screw terminal.
- 54

## 55 2.09 EQUIPMENT WIRING

- 56
- 57 A. See plans for approximate location and sizes of all lighting equipment wiring. Verify exact
- 58 locations at job site with the contractor that is furnishing the lighting equipment.

1  
2 B. The Drawings indicate that the anticipated loads and circuit sizes. Verify all these requirements  
3 with the site lighting contractor and install accordingly under this contract.  
4

5 C. All final connections to motors to be made by this Contractor.  
6

## 7 **2.10 SAFETY SWITCHES**

8

9 A. Provide safety switches of general duty type, horsepower rated, quick-make and quick-break  
10 design, externally operated with provision for padlocking, fusible or non-fusible as shown on the  
11 Drawings.  
12

13 B. Provide enclosures clearly marked for maximum voltage, current, and horsepower rating, and:  
14

- 15 1. Indoor: NEMA type 1.
- 16 2. Outdoor: NEMA type 3R, raintight.  
17

18 C. Approved Manufacturers: Square D, Cutler Hammer or Siemens.  
19  
20

## 21 **2.11 OTHER MATERIALS**

22

23 A. Provide other materials, not specifically described but required for a complete and proper  
24 installation, as selected by the Contractor subject to the approval of the Architect.  
25  
26

## 27 **PART 3 - EXECUTION**

28

### 29 **3.01 SURFACE CONDITIONS**

30

31 A. Examine the areas and conditions under which work of this Section will be performed. Correct  
32 conditions detrimental to timely and proper completion of the Work. Do not proceed until  
33 unsatisfactory conditions are corrected.  
34

### 35 **3.02 PREPARATION**

36

37 A. Coordination:  
38

- 39 1. Coordinate as necessary with other trades to assure proper and adequate provision in  
40 the work of those trades for interface with the work of this Section.
- 41 2. Coordinate the installation of electrical items with the schedule for work of other trades to  
42 prevent unnecessary delays in the work schedule.  
43

44 B. Data indicated on the Drawings and in these Specifications are as exact as could be secured, but  
45 their absolute accuracy is not warranted. The exact locations, distances, levels, and other  
46 conditions will be governed by actual construction and the Drawings and Specifications should be  
47 used only for guidance in such regard.  
48

49 C. Where outlets are not specifically located on the Drawings, locate as determined in the field by  
50 the Architect. Where outlets are installed without such specific direction, relocate as directed by  
51 the Architect and at no additional cost to the Owner.  
52

53 D. Verify all measurements at the building. No extra compensation will be allowed because of  
54 differences between work shown on the drawings and actual measurements at the site of  
55 construction.  
56

57 E. The Electrical Drawings are diagrammatic, but are required to be followed closely as actual  
58 construction and work of other trades will permit. Where deviations are required to conform with

1 actual construction and the work of other trades, make such deviations without additional cost to  
2 the Owner.

### 3 4 **3.03 INSTALLATION OF ELECTRIC SERVICE**

- 5  
6 A. Coordinate installation with local utility as required for a complete electric service installation.  
7  
8 B. Installation shall be approved by the local utilities.  
9

### 10 **3.04 TRENCHING AND BACKFILLING**

- 11  
12 A. Perform trenching and backfilling associated with the work of this Section in strict  
13 accordance with the provisions of Division 2 of these Specifications.  
14  
15 B. Cut bottom of trench to grade, make trench 12" wider than the widest dimension of the pipe.  
16  
17 C. Bedding and backfilling:  
18  
19 1. Install piping promptly after trenching. Keep trenches open as short a time as  
20 practicable.  
21 2. *Under the building slab:* Install all pipes on a compacted bed of damp sand 6" deep. Do  
22 not lay piping on large stones, rocks or bricks.  
23 3. *Outside the building:* Install all underground piping on a compacted bed of damp sand  
24 6" deep. Backfill to within 12" of finish grade with damp sand. Backfill the remainder with  
25 native topsoil. Backfill in layers and compact sufficiently to prevent settlement.  
26 4. Do not start backfill operations until underground plumbing work has been properly  
27 inspected and approved by governing authorities.  
28

### 29 **3.05 INSTALLATION OF RACEWAYS AND FITTINGS**

- 30  
31 A. Where conduit is installed concealed in walls or above ceiling, or exposed in work areas, provide  
32 rigid galvanized conduit or electrical metallic tubing with compression type fittings.  
33  
34 1. Seal joints to prevent entrance of water.  
35 2. Provide ground wire of proper size per NEC 250.  
36 3. Use nylon (rather than steel) fish tape.  
37  
38 B. Use flexible conduit only for short motor connections, or where subject to vibration.  
39  
40 C. Provide necessary sleeves and chases where conduits pass through floors and walls and provide  
41 other necessary openings and spaces, arranging for proper time to prevent unnecessary cutting  
42 in connection with the Work.  
43  
44 D. Where conduit is exposed, run parallel to or at right angle with lines of the building.  
45  
46 E. Securely and rigidly support conduits throughout the work.  
47  
48 F. Provide tracing tape 6" above non-metallic underground conduit.  
49

### 50 **3.06 INSTALLATION OF LIGHTING EQUIPMENT**

- 51  
52 A. Provide power and control wiring for lighting equipment as shown on the Drawings.  
53

### 54 **3.07 INSTALLATION OF CONDUCTORS**

- 55  
56 A. Unless otherwise shown on the Drawings or noted in these Specifications, use No. 12 AWG  
57 conductors for all branch circuits, protected by 20 amp circuit breakers. For runs exceeding 100  
58 feet, use larger wires to limit voltage drops.

- 1  
2 B. Use identified (white) neutrals and color-coded phase wires for all branch circuit wiring.  
3  
4 1. Make splices electrically and mechanically secure with pressure-type connectors.  
5 2. Provide "Scotchlok", Buchanon "B-cap", or Ideal "Wing-nut" connectors for wires sizes 6  
6 AWG and smaller.  
7 3. Provide Burndy compression-type connectors, "Hydent" or equal applied with a  
8 mechanical tool and die equipment for wire sizes 4 AWG and larger.  
9 4. Insulate splices with a minimum of two half-lapped layers of Scotch Branch No. 33 vinyl-  
10 plastic electrical tape where insulation is required.  
11

### 12 **3.08 INSTALLATION OF PANELBOARDS**

- 13  
14 A. Unless otherwise shown on the Drawings, install panels with the top of the trim 6'-3" above the  
15 finished floor.  
16  
17 B. Mount a typewritten directory behind plastic on the inside of each panel door and on the  
18 directory, showing the circuit number and complete description of all outlets on each circuit.  
19  
20 C. Provide two (2) spare 1" conduits, stubbed out of the top of each flush-mounted panel and  
21 terminated in accessible ceiling space, with each conduit tagged with panel description.  
22

### 23 **3.09 TESTING AND INSPECTION**

- 24  
25 A. Provide personnel and equipment, make required tests, and secure required approvals from the  
26 Architect and governmental agencies having jurisdiction.  
27  
28 B. Make written notice to the Architect adequately in advance of each of the following stages of  
29 construction:  
30  
31 1. Test all parts of the electrical system and prove that all such items provided under this  
32 Section function electrically in the required manner.  
33 2. Immediately submit to the Architect a report of maximum and minimum voltages and a  
34 copy of the recording volt-meter chart.  
35 3. Also measure voltages between phases and between phase wires and neutrals and  
36 report these voltages to the Architect.  
37

### 38 **3.10 PROJECT COMPLETION**

- 39  
40 A. Upon completion of the work of this Section, thoroughly clean all exposed portions of the  
41 electrical installation, removing all traces of soil, labels, grease, oil, and other foreign material,  
42 and using only the type cleaner recommended by the manufacturer of the item being cleaned.  
43  
44 B. Thoroughly indoctrinate the Owner's operation and maintenance personnel in the contents of the  
45 operations and maintenance manual required to be submitted under Article 1.3 of this Section of  
46 these Specifications.  
47

48 **END OF SECTION**