



- GENERAL NOTES:**
- NO DRILLING OF THE ROOF SLAB OVER RESERVOIR IS ALLOWED.
 - ALL LIGHTING ON THIS SHEET SHALL BE POWERED FROM NEW CIRCUIT BREAKERS IN PANEL B THROUGH CONTACTORS IN THE LIGHTING CONTROL CABINET. SEE DRAWING E1.2 FOR ADDITIONAL BRANCH CIRCUIT REQUIREMENTS. SEE LIGHTING CIRCUIT SCHEDULE ON DRAWING E5.1 FOR WIRING REQUIREMENTS.
 - CIRCUIT NUMBERS INDICATE FIXTURES ON THE SAME CIRCUIT AND DO NOT NECESSARILY CORRESPOND TO LIGHTING PANEL CIRCUIT NUMBERS.
 - POLE LOCATIONS ARE APPROXIMATE. COORDINATE EXACT POLE LOCATIONS WITH EXISTING CONDUIT, JUNCTION BOXES, ETC. IDENTIFY AND CONFIRM EXACT LOCATION WITH OWNER AND ENGINEER PRIOR TO POLE BASE CONSTRUCTION.
 - MOUNT CONDUIT BELOW WALL CAP ADJACENT TO EXISTING CONDUIT.
 - PROVIDE CONCRETE BASES AND CONDUIT FOR FUTURE LIGHT POLES AS SHOWN. LIGHT POLES AND WIRING WILL BE PROVIDED IN A FUTURE PROJECT.
 - PROVIDE JUNCTION BOXES AND 1" CONDUIT FROM JUNCTION BOX INTO CONCRETE BASE AS AT EACH BASE (NOT SHOWN FOR CLARITY) FOR ROUTING PROPOSED/FUTURE LIGHTING CIRCUIT CONDUCTORS INTO LIGHT POLE.

- KEY NOTES:**
- IF REMOVAL OF FENCE FABRIC IS REQUIRED FOR CONDUIT INSTALLATION, FENCE SHALL BE REINSTALLED TO EXISTING CONDITIONS.
 - ROUTE CONDUIT ALONG THE BOTTOM PORTION OF THE OPENING. PROVIDE JUNCTION BOXES AS REQUIRED.
 - CENTER FIXTURE WITH LOWER STAIRWAY BELOW WALL CAP.
 - COORDINATE LOCATION OF ROOF PENETRATION FOR CONDUITS WITH OWNER AND ENGINEER. PROVIDE WEATHERPROOF SEALING AROUND ROOF PENETRATIONS, INCLUDING A ROOF FLASHING FOR EACH CONDUIT.
 - PROVIDE 4~#14 IN 3/4" CONDUIT FROM CONTROL STATION TO LIGHTING CONTROL CABINET. SEE DRAWING E1.2.

NO.	REVISIONS	DATE
1	ISSUED FOR BID	12/26/19
2	ADDENDUM NO. 2	1/8/20

ELECTRICAL ROOF PLAN
 REYNOLDS PARK - WATER UTILITY ROOFTOP LIGHTING
 CITY OF MADISON
 MADISON, WISCONSIN

JOB NO.
1020.118
PROJECT MGR.
MARY SEEHAFFER



SHEET
5
E1.0