



Department of Public Works
Engineering Division
Kathy Cryan, Interim Engineering Manager

City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4751
Fax: (608) 264-9275
engineering@cityofmadison.com
www.cityofmadison.com/engineering

Deputy City Engineer
Gregory T. Fries, P.E.
Principal Architect 2
Bryan Cooper, AIA
Principal Engineer 2
John S. Fahrney, P.E.
Chris Petykowski, P.E.
Janet Schmidt, P.E.
Principal Engineer 1
Christina M. Bachmann, P.E.
Mark D. Moder, P.E.
James M. Wolfe, P.E.
Financial Manager
Steven B. Danner-Rivers

August 22, 2022

**NOTICE OF ADDENDUM
ADDENDUM NO. 1**

**CONTRACT NO. 8654, PROJECT NO. 44001
West Badger Road Salt Barn**

This addendum is issued to modify, explain or correct the original Drawings, Specifications, or Contract Documents marked as *West Badger Road Salt Barn, City of Madison Project 44001, Contract #8654, as issued on July 27, 2022* and is hereby made a part of the contract documents. This addendum consists of two (2) pages and the referenced exhibit. This addendum represents clarifications of the original documents and a minor change in the demolition scope only, therefore no extension to the bid due date will be considered.

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

An electronic version of these documents can be found on the Bid Express web site at:
<http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

For questions regarding this bid, contact:

Randy Wiesner
City of Madison Engineering
Phone: 608-267-8679
Fax: 608-264-9275
Email: RWiesner@cityofmadison.com

Sincerely,

For:
Kathy Cryan, Interim Engineering Manager

Cc: Greg Fries



1. **GENERAL CONTRACT CONDITIONS**

There are no changes to the general contract conditions.

2. **GENERAL QUESTIONS/ANSWERS and CLARIFICATIONS**

Q1. Can the path for the utility trench be amended as there is a significant amount of equipment in the Brine Room adding difficulty of getting conduit around this equipment?

A1. Yes. The plan sheets have been modified to show a new route. See item 5 below for descriptions.

Q2. Can you verify the location of the CAT6 conduits in the Cold Storage Building for the security cameras, no conduit is visible in the Brine Room or Equipment Room?

A2. After review with City Information Technology and on site staff there is no conduit and cabling for the security cameras. Data connection is achieved by point to point data antennas. See item 5 below for descriptions.

3. **ACCEPTABLE EQUIVALENTS**

No requests for alternates have been received therefore no alternates will be reviewed during the construction process.

4. **SPECIFICATIONS**

There were no changes to any of the written specifications in Exhibit B.

5. **DRAWINGS**

A. The following changes were made to the Exhibit A Plan set. These corrected sheets will be published as Exhibit E.

i. Sheet 1; demolition and removal of 2 area light poles as follows:

- Remove (2) Point to Point Data Antennas, retain for reinstallation.

ii. Sheet 2; reinstall (2) salvaged PTZ cameras.

- Reinstall (2) salvaged Point to Point Data Antennas and connect to reinstalled PTZ cameras.
- Coordinate reinstallation, alignment and testing with City IT Divisions through City Project Manager.
- Delete all reference of installing new data conduits and data cabling.

iii. Sheet 2; Revised location for utility trench. Also see revised quantity on Bid Proposal form.

iv. Sheet 7; Delete all references of installing new data conduits and cabling

6. **PROPOSAL**

The drawing changes in item 5 above shall be incorporated into the appropriate bid items as follows:

A. Changes to sheet 1 regarding demolition and salvage of existing point to point antennas for camera equipment shall be included with Bid Item 90000 Demolition of Existing Buildings.

B. The quantity for Bid Item 50226 has been changed to reflect the revised route for the electrical trench as depicted on sheet 2.

C. Changes to sheets 2 and 7 regarding the reinstallation of existing point to point antennas for camera equipment shall be included with Bid Item 90003 Construct Bulk Storage Salt Building.

Note: The following contractors were present for the Pre-Bid Walk-through on Monday August 8, 2022

- Gavin Jasmer, Tri-North Builders, havinjasmer@gmail.com, 608-204-7239
- Jamie Baake, Midwest Electric, jbaake@mwelectric.net, 262-352-6759

End of Contract 8654 Addendum 1.