



Legend

⊙ Denotes Boring Location



Notes

1. Soil borings performed by America's Drilling Co. in February 2024
2. Boring locations are approximate

Scale: Reduced

| | |
|----------------------|--|
| Date: 2/2024 | |
| Job No. C23051-21 | |

Soil Boring Location Map
Pflaum Rd
Madison, WI



LOG OF TEST BORING

Project Pflaum Road
 Location 50'E of Admiral, 15'N of Centerline
Madison, WI

Boring No. 1
 Surface Elevation (ft) 902±
 Job No. C23051-21
 Sheet 1 of 1

2921 Perry Street, Madison, WI 53713 (608) 288-4100, FAX (608) 288-7887

| SAMPLE | | | | | VISUAL CLASSIFICATION and Remarks | SOIL PROPERTIES | | | | |
|--------|--------------|-------|----|---------------|---|--|---|----|----|-----|
| No. | Rec (in.) | Moist | N | Depth (ft) | | qu (qa) (tsf) | W | LL | PL | LOI |
| | | | | 0 | X | 4 in. Asphalt Pavement/7 in. Base Course | | | | |
| 1 | 16 | M | 22 | 22 | | | | | | |
| | | | | 5 | | | | | | |
| 2 | 6 | M | 12 | 12 | | | | | | |
| | | | | 10 | | | | | | |
| 3 | 14 | M | 25 | 25 | | | | | | |
| | | | | 15 | End of Boring at 15 ft | | | | | |
| 4 | 14 | M | 32 | 32 | Backfilled with Bentonite Chips and Asphalt Patch | | | | | |
| | | | | 20 | | | | | | |
| 5 | 12 | M | 51 | 51 | | | | | | |

WATER LEVEL OBSERVATIONS

GENERAL NOTES

While Drilling ∇ NW Upon Completion of Drilling _____
 Time After Drilling _____
 Depth to Water _____
 Depth to Cave in _____

Start 2/2/24 End 2/2/24
 Driller ADC Chief KD Rig CME-55
 Logger DB Editor ESF
 Drill Method 2.25" HSA; Autohammer

The stratification lines represent the approximate boundary between soil types and the transition may be gradual.



LOG OF TEST BORING

Project Pflaum Road
225'E of Alder, 15'N of Centerline
 Location Madison, WI

Boring No. 2
 Surface Elevation (ft) 905±
 Job No. C23051-21
 Sheet 1 of 1

2921 Perry Street, Madison, WI 53713 (608) 288-4100, FAX (608) 288-7887

| SAMPLE | | | | | VISUAL CLASSIFICATION and Remarks | SOIL PROPERTIES | | | | |
|---|------|--------------|-------|-------|--------------------------------------|--|---------------------|---|----|----|
| No. | TYPE | Rec (in.) | Moist | N | | Depth (ft) | qu (qa) (tsf) | W | LL | PL |
| | | | | | 0 | 8 in. Asphalt Pavement/5 in. Base Course | | | | |
| 1 | AS | 0 | M | 14 | 0 | FILL: Medium Stiff Brown Clay with Sand and Gravel | | | | |
| 2 | | 10 | M | 3 | 10 | Medium Stiff to Stiff, Brown Lean CLAY (CL; Possible Fill) | | | | |
| 3 | | 12 | M | 7 | 12 | (0.75) | | | | |
| 4 | | 12 | M | 8 | 12 | Loose, Dark Brown Clayey SAND, Trace Gravel (SC; Possible Fill) | | | | |
| 5 | | 8 | M | 21 | 10 | Medium Dense to Very Dense, Brown Fine to Medium SAND, Some Silt and Gravel, Scattered Cobbles and Boulders (SM) | | | | |
| 6 | | 5 | M/W | 56/8" | 15 | End of Boring at 15 ft | | | | |
| Backfilled with Bentonite Chips and Asphalt Patch | | | | | | | | | | |

| WATER LEVEL OBSERVATIONS | | | | | GENERAL NOTES | | | | |
|---|-------------------------------------|----|-----------------------------|-------------------------------------|---------------|-----------------------|--------|--------|------------|
| While Drilling | <input checked="" type="checkbox"/> | NW | Upon Completion of Drilling | <input type="checkbox"/> | Start | 2/1/24 | End | 2/1/24 | |
| Time After Drilling | | | | | Driller | ADC | Chief | KD | Rig CME-55 |
| Depth to Water | | | | <input checked="" type="checkbox"/> | Logger | PB | Editor | ESF | |
| Depth to Cave in | | | | | Drill Method | 2.25" HSA; Autohammer | | | |
| The stratification lines represent the approximate boundary between soil types and the transition may be gradual. | | | | | | | | | |



LOG OF TEST BORING

Project Pflaum Road
215'E of Camden, 15'S of Centerline
 Location Madison, WI

Boring No. 3
 Surface Elevation (ft) 897±
 Job No. C23051-21
 Sheet 1 of 1

2921 Perry Street, Madison, WI 53713 (608) 288-4100, FAX (608) 288-7887

| SAMPLE | | | | | VISUAL CLASSIFICATION and Remarks | SOIL PROPERTIES | | | | |
|--------|----------------|--------------|-------|-------|---|-----------------|---------------------|---|----|----|
| No. | Embed (in.) | Rec (in.) | Moist | N | | Depth (ft) | qu (qa) (tsf) | w | LL | PL |
| | | | | | 4.5 in. Asphalt Pavement/7 in. Base Course | | | | | |
| 1 | | 12 | M | 19 | FILL: Medium Dense Dark Gray Silt with Sand and Gravel | | | | | |
| | | | | | Stiff, Brown Lean CLAY (CL) | | | | | |
| 2 | | 14 | M | 9 | | (1.5) | | | | |
| | | | | | Medium Dense to Dense, Brown Fine to Medium SAND, Some Silt and Gravel, Scattered Cobbles and Boulders (SM) | | | | | |
| 3 | | 6 | M | 23 | | | | | | |
| | | | | | Weathered to Competent Light Brown to White Sandstone Bedrock | | | | | |
| 4 | | 8 | M | 33 | | | | | | |
| 5 | | 5 | M | 50/5" | End of Boring at 15 ft | | | | | |
| | | | | | Backfilled with Bentonite Chips and Asphalt Patch | | | | | |

WATER LEVEL OBSERVATIONS

GENERAL NOTES

While Drilling NW Upon Completion of Drilling _____
 Time After Drilling _____
 Depth to Water _____
 Depth to Cave in _____

Start 2/2/24 End 2/2/24
 Driller ADC Chief DB Rig CME-55
 Logger KD Editor ESF
 Drill Method 2.25" HSA; Autohammer

The stratification lines represent the approximate boundary between soil types and the transition may be gradual.

LOG OF TEST BORING
General Notes

DESCRIPTIVE SOIL CLASSIFICATION

Grain Size Terminology

| Soil Fraction | Particle Size | U.S. Standard Sieve Size |
|---------------------|-----------------------------|--------------------------|
| Boulders | Larger than 12" | Larger than 12" |
| Cobbles | 3" to 12" | 3" to 12" |
| Gravel: Coarse..... | ¾" to 3" | ¾" to 3" |
| Fine | 4.76 mm to ¾" | #4 to ¾" |
| Sand: Coarse..... | 2.00 mm to 4.76 mm..... | #10 to #4 |
| Medium | 0.42 to mm to 2.00 mm | #40 to #10 |
| Fine | 0.074 mm to 0.42 mm..... | #200 to #40 |
| Silt..... | 0.005 mm to 0.074 mm..... | Smaller than #200 |
| Clay..... | Smaller than 0.005 mm..... | Smaller than #200 |

Plasticity characteristics differentiate between silt and clay.

General Terminology

Physical Characteristics
 Color, moisture, grain shape, fineness, etc.
Major Constituents
 Clay, silt, sand, gravel
Structure
 Laminated, varved, fibrous, stratified,
 cemented, fissured, etc.
Geologic Origin
 Glacial, alluvial, eolian, residual, etc.

Relative Density

| Term | "N" Value |
|-------------------|-----------|
| Very Loose..... | 0 - 4 |
| Loose..... | 4 - 10 |
| Medium Dense..... | 10 - 30 |
| Dense..... | 30 - 50 |
| Very Dense..... | Over 50 |

Relative Proportions Of Cohesionless Soils

| Proportional Term | Defining Range by Percentage of Weight |
|-------------------|--|
| Trace..... | 0% - 5% |
| Little..... | 5% - 12% |
| Some..... | 12% - 35% |
| And | 35% - 50% |

Consistency

| Term | q _u -tons/sq. ft |
|-----------------|-----------------------------|
| Very Soft..... | 0.0 to 0.25 |
| Soft..... | 0.25 to 0.50 |
| Medium..... | 0.50 to 1.0 |
| Stiff..... | 1.0 to 2.0 |
| Very Stiff..... | 2.0 to 4.0 |
| Hard..... | Over 4.0 |

Organic Content by Combustion Method

| Soil Description | Loss on Ignition |
|---------------------------|------------------|
| Non Organic..... | Less than 4% |
| Organic Silt/Clay..... | 4 - 12% |
| Sedimentary Peat..... | 12% - 50% |
| Fibrous and Woody Peat... | More than 50% |

Plasticity

| Term | Plastic Index |
|----------------------|---------------|
| None to Slight..... | 0 - 4 |
| Slight..... | 5 - 7 |
| Medium..... | 8 - 22 |
| High to Very High .. | Over 22 |

The penetration resistance, N, is the summation of the number of blows required to effect two successive 6" penetrations of the 2" split-barrel sampler. The sampler is driven with a 140 lb. weight falling 30" and is seated to a depth of 6" before commencing the standard penetration test.

SYMBOLS

Drilling and Sampling

- CS – Continuous Sampling
- RC – Rock Coring: Size AW, BW, NW, 2"W
- RQD – Rock Quality Designation
- RB – Rock Bit/Roller Bit
- FT – Fish Tail
- DC – Drove Casing
- C – Casing: Size 2 ½", NW, 4", HW
- CW – Clear Water
- DM – Drilling Mud
- HSA – Hollow Stem Auger
- FA – Flight Auger
- HA – Hand Auger
- COA – Clean-Out Auger
- SS – 2" Dia. Split-Barrel Sample
- 2ST – 2" Dia. Thin-Walled Tube Sample
- 3ST – 3" Dia. Thin-Walled Tube Sample
- PT – 3" Dia. Piston Tube Sample
- AS – Auger Sample
- WS – Wash Sample
- PTS – Peat Sample
- PS – Pitcher Sample
- NR – No Recovery
- S – Sounding
- PMT – Borehole Pressuremeter Test
- VS – Vane Shear Test
- WPT – Water Pressure Test

Laboratory Tests

- q_a – Penetrometer Reading, tons/sq ft
- q_u – Unconfined Strength, tons/sq ft
- W – Moisture Content, %
- LL – Liquid Limit, %
- PL – Plastic Limit, %
- SL – Shrinkage Limit, %
- LI – Loss on Ignition
- D – Dry Unit Weight, lbs/cu ft
- pH – Measure of Soil Alkalinity or Acidity
- FS – Free Swell, %

Water Level Measurement

- ∇ - Water Level at Time Shown
- NW – No Water Encountered
- WD – While Drilling
- BCR – Before Casing Removal
- ACR – After Casing Removal
- CW – Cave and Wet
- CM – Caved and Moist
















Note: Water level measurements shown on the boring logs represent conditions at the time indicated and may not reflect static levels, especially in cohesive soils.

CGC, Inc.

Madison - Milwaukee

Unified Soil Classification System

UNIFIED SOIL CLASSIFICATION AND SYMBOL CHART

| COARSE-GRAINED SOILS (more than 50% of material is larger than No. 200 sieve size) | | |
|---|--|--|
| GRAVELS More than 50% of coarse fraction larger than No. 4 sieve size | Clean Gravels (Less than 5% fines) | |
| |  GW | Well-graded gravels, gravel-sand mixtures, little or no fines |
| |  GP | Poorly-graded gravels, gravel-sand mixtures, little or no fines |
| | Gravels with fines (More than 12% fines) | |
| |  GM | Silty gravels, gravel-sand-silt mixtures |
| |  GC | Clayey gravels, gravel-sand-clay mixtures |
| SANDS 50% or more of coarse fraction smaller than No. 4 sieve size | Clean Sands (Less than 5% fines) | |
| |  SW | Well-graded sands, gravelly sands, little or no fines |
| |  SP | Poorly graded sands, gravelly sands, little or no fines |
| | Sands with fines (More than 12% fines) | |
| |  SM | Silty sands, sand-silt mixtures |
| |  SC | Clayey sands, sand-clay mixtures |
| FINE-GRAINED SOILS (50% or more of material is smaller than No. 200 sieve size.) | | |
| SILTS AND CLAYS Liquid limit less than 50% |  ML | Inorganic silts and very fine sands, rock flour, silty or clayey fine sands or clayey silts with slight plasticity |
| |  CL | Inorganic clays of low to medium plasticity, gravelly clays, sandy clays, silty clays, lean clays |
| |  OL | Organic silts and organic silty clays of low plasticity |
| SILTS AND CLAYS Liquid limit 50% or greater |  MH | Inorganic silts, micaceous or diatomaceous fine sandy or silty soils, elastic silts |
| |  CH | Inorganic clays of high plasticity, fat clays |
| |  OH | Organic clays of medium to high plasticity, organic silts |
| HIGHLY ORGANIC SOILS |  PT | Peat and other highly organic soils |

LABORATORY CLASSIFICATION CRITERIA

| | | |
|----|---|---|
| GW | $C_u = \frac{D_{60}}{D_{10}}$ greater than 4; $C_c = \frac{D_{30}}{D_{10} \times D_{60}}$ between 1 and 3 | |
| GP | Not meeting all gradation requirements for GW | |
| GM | Atterberg limits below "A" line or P.I. less than 4 | Above "A" line with P.I. between 4 and 7 are borderline cases requiring use of dual symbols |
| GC | Atterberg limits above "A" line or P.I. greater than 7 | |
| SW | $C_u = \frac{D_{60}}{D_{10}}$ greater than 4; $C_c = \frac{D_{30}}{D_{10} \times D_{60}}$ between 1 and 3 | |
| SP | Not meeting all gradation requirements for GW | |
| SM | Atterberg limits below "A" line or P.I. less than 4 | Limits plotting in shaded zone with P.I. between 4 and 7 are borderline cases requiring use of dual symbols |
| SC | Atterberg limits above "A" line with P.I. greater than 7 | |

Determine percentages of sand and gravel from grain-size curve. Depending on percentage of fines (fraction smaller than No. 200 sieve size), coarse-grained soils are classified as follows:

Less than 5 percent GW, GP, SW, SP
 More than 12 percent GM, GC, SM, SC
 5 to 12 percent Borderline cases requiring dual symbols

