



Department of Public Works
Engineering Division
Robert F. Phillips, P.E., City Engineer
City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4751
Fax: (608) 264-9275
engineering@cityofmadison.com
www.cityofmadison.com/engineering

Deputy City Engineer
Gregory T. Fries, P.E.
Deputy Division Manager
Kathleen M. Cryan
Principal Engineer 2
Christopher J. Petykowski, P.E.
John S. Fahrney, P.E.
Janet Schmidt, P.E.
Principal Engineer 1
Christina M. Bachmann, P.E.
Mark D. Moder, P.E.
James M. Wolfe, P.E.
Facilities & Sustainability
Bryan Cooper, Principal Architect
Mapping Section Manager
Eric T. Pederson, P.S.
Financial Manager
Steven B. Danner-Rivers

June 18, 2021

**NOTICE OF ADDENDUM
ADDENDUM NO. 2
CONTRACT NO. 9042**

MADISON FIRE STATION 05 WALL REMOVAL & IMPROVEMENTS

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

SECTION 109.7 TIME OF COMPLETION

The Contractor shall complete all work on or before January 31, 2022.

Work shall begin only after the start work letter is received. The start work letter is anticipated to be issued on or about August 16, 2021. The contractor shall notify the City Project Manager three (3) weeks in advance of the selected start date to begin work on-site, with work completed within 42 days.

GENERAL QUESTIONS AND ANSWERS:

- A. **Q:** Please provide clarification of the requirements for the replacement window indicated on Notes 6 and 7 of sheet A1 regarding glass type and frame finish.
A: Add the following to Note 6: Basis of Design: EFCO Series 403 (or equal), 2" x 4 1/2" Thermal Storefront Framing with 1" thermal pane, standard clear tempered glass. No e-coating required. Frame to be clear anodized finish.
Note 7 should be corrected to state that the window TRIM shall be painted. The window frame shall not be painted.

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:
<http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

Sincerely,

Christy Bachmann on behalf of
Robert F. Phillips, P.E., City Engineer