



Department of Public Works
Engineering Division
James M. Wolfe, P.E., City Engineer

City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4751
Fax: (608) 264-9275
engineering@cityofmadison.com
www.cityofmadison.com/engineering

Assistant City Engineer
Bryan Cooper, AIA
Gregory T. Fries, P.E.
Chris Petykowski, P.E.
Deputy Division Manager
Kathleen M. Cryan
Principal Engineer 2
John S. Fahrney, P.E.
Janet Schmidt, P.E.
Principal Engineer 1
Mark D. Moder, P.E.
Andrew J. Zwieg, P.E.
Financial Manager
Steven B. Danner-Rivers

August 8, 2023

**NOTICE OF ADDENDUM
ADDENDUM 1
CONTRACT NO. 9335
CIPP LINING REHABILITATION OF SANITARY SEWERS PHASE 2 - 2023**

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

PLANS:

Remove and replace the sheet P-3 and P-4 with the attached plan sheets. Sheets were revised to call out the presence of a sanitary force main that flows into mains that are to be lined.

SPECS:

ADD FOLLOWING TO SECTION 509.3(c) OF THE SPECIAL PROVISIONS:

The force main from the City of Madison Mayflower Lift Station outlets into SAS #4964-001. The lift station runs an average of 10 minutes an hour at a flow rate of 400 gpm. Flow from the lift station and force main shall be maintained at all times.


Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:

<http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

Sincerely,


for James M. Wolfe, P.E., City Engineer