

Listing of Module Types:

1- V14 ALD	2- V14 ALD
250- V7 Annunciator Panel	251- V7 Annunciator Panel
253- V6 MXL-IQ Panel	254- MXL-IQ field programmer

Listing of Device Types in Module 2 (ALD):

1- ID-60P Photo Detector	2- ID-60P Photo Detector
3- ID-60P Photo Detector	4- TRI-2/60 Switch Input
5- ID-60P Photo Detector	6- ID-60P Photo Detector
7- ID-60P Photo Detector	8- ID-60P Photo Detector
9- ID-60P Photo Detector	10- ID-60P Photo Detector
11- ID-60T-135 Thermal Detector	12- ID-60P Photo Detector
13- ID-60P Photo Detector	14- ID-60P Photo Detector
15- TRI-2/60 Switch Input	16- TRI-2/60 Switch Input
17- TRI-2/60 Switch Input	18- TRI-2/60 Switch Input
19- ID-60P Duct Photo Detector	20- ID-60T-135 Thermal Detector
21- ID-60T-135 Thermal Detector	22- TRI-2/60 Switch Input
23- FP-11 Photo Thermal Detector	24- TRI-2/60 Switch Input
25- ID-60P Photo Detector	26- TRI-2/60 Switch Input
60- TRI-2/60 Switch Input	

Listing of Messages in Module 2 (ALD):

1- SMOKE STORAGE ROOM 104	2- SMOKE CORRIDOR
3- SMOKE IN ENTRYWAY	4- PULLSTATION ENTRYWAY
5- SMOKE FRONT ENTRYWAY	6- SMOKE ABOVE RECEPTION DESK
7- SMOKE WEST CORRIDOR HALL	8- SMOKE WEST CORRIDOR
9- SMOKE ROOM 143 STORAGE	10- SMOKE IN ROOM 140
11- HEAT IN KITCHEN	12- SMOKE IN CORRIDOR WEST
13- SMOKE IN CORRIDOR WEST	14- SMOKE IN CORRIDOR WEST
15- FULLSTATION WEST EXIT	16- FULLSTATION COMMUNITY ROOM
17- FULLSTATION COMMUNITY ROOM	18- FULLSTATION COMMUNITY ROOM
19- SMOKE IN ENTRYWAY	20- HEAT SOUTH MEZZANINE
21- HEAT SOUTH MEZZANINE	22- FULLSTATION SOUTH MEZZANINE
23- DUCT SMOKE IN SOUTH MEZZANINE	24- FULLSTATION WEST EXIT
25- SMOKE ENTRYWAY	26- TRI KITCHEN HOOD RELEASE SYSTEM
60- TROUBLE TRI ON PAD2	

Listing of Device Types in Module 1 (ALD):

1- ID-60P Photo Detector	2- ID-60P Photo Detector
3- ID-60P Photo Detector	4- ID-60P Photo Detector
5- TRI-2/60 Switch Input	6- ID-60P Photo Detector
7- ID-60P Photo Detector	8- TRI-2/60 Switch Input
9- ID-60T-135 Thermal Detector	10- TRI-2/60 Switch Input
11- ID-60P Photo Detector	12- ID-60P Photo Detector
13- ID-60P Photo Detector	14- ID-60P Photo Detector
15- ID-60P Photo Detector	16- ID-60T-135 Thermal Detector
17- ID-60P Photo Detector	18- ID-60P Photo Detector
19- ID-60P Photo Detector	25- ID-60T-135 Thermal Detector
26- ID-60T-135 Thermal Detector	27- TRI-2/60 Switch Input
28- FP-11 Photo Thermal Detector	29- FP-11 Photo Thermal Detector
31- TRI-2/60D Dual Switch Input	32- TRI-2/60D Dual Switch Input
33- TRI-2/60 Switch Input	

Listing of Messages in Module 1 (ALD):

1- SMOKE IN FACP ROOM	2- SMOKE IN CORRIDOR
3- SMOKE IN CORRIDOR	4- SMOKE IN CORRIDOR
5- FULLSTATION SOUTH EXIT	6- SMOKE RM 107 WORKSHOP STORAGE
7- SMOKE SOUTH STAIRWAY	8- FULLSTATION SOUTH STAIRWAY
9- HEAT IN JANITOR ROOM 109	10- FULLSTATION GYMNASIUM
11- SMOKE GAME ROOM 121	12- SMOKE GAME ROOM 121
13- SMOKE IN STORAGE ROOM 123	14- SMOKE IN ROOM 128 STORAGE
15- SMOKE IN ROOM 130 STORAGE	16- HEAT IN ROOM 131
17- SMOKE IN ROOM 134 STORAGE	18- SMOKE IN ROOM 134 INFANTS
19- SMOKE CHILD CARE RM 136	25- HEAT NORTH MEZZANINE
26- HEAT NORTH MEZZANINE	27- FULLSTATION NORTH MEZZANINE
28- DUCT SMOKE NORTH MEZZANINE	29- DUCT SMOKE IN NORTH MEZZANINE
31- WATER FLOW SPRINKLER SYSTEM	32- TAMPER SPRINKLER SYSTEM
33- TAMPER SPRINKLER SYSTEM	

Bill of Materials

Fire Alarm System

1	MXL-IQ	Fire Alarm Control Panel
2	ASLA	Batteries
1	RCC-1F	Annunciator
7	MSI-10B	Manual Pull Stations
26	FP-11	Smoke Detectors
26	DB-11	Bases for Above
7	ILT-1	Heat Detectors
7	DB-3S	Bases for Above
1	PAL-1	Printer
1	PIM-1	Printer Module
1	PIM-2	Printer Module
13	MT-241575	Horn Strobe
15	RS-241575	Strobe Light
1	PS-12/24-6	Power Booster
2	ASLA	Batteries