

P.O. Box 708 • Poynette, WI 53955 Phone: (608) 240-1511 • Email: Office@aaenv.com • Fax: (608) 635-9717

November 9, 2016

David C. Schaller City of Madison 215 Martin Luther King Jr. Blvd, Room 115 Madison, WI 53703 (608) 243-5891, Fax (608) 264-9275 Dschaller@cityofmadison.com

RE: 1301 W. Badger Road

Dave,

I went back to the Library Support Center on my own with all of my field notes to save myself from more embarrassment by sorting out the door caulking issue.

I also looked at the lead paint in the warehouse. Depending on which standard you use, the new DHS standard is 1.0 Mg/Cm², the DNR standard for recycling concrete is 0.7 Mg/Cm², and the OSHA standard is 0.00 Mg/Cm².

The yellow paint on the warehouse floor and dock area which amounts to approximately 220 Sq. Ft has the highest level of lead in yellow paint. Most of the paint is intact however it is starting to peel. Please let me know your thoughts.

There is approximately 435 Sq Ft of red and yellow paint on the bottom of the steel support beams in twenty one different locations. What are your plans, just paint or strip and repaint?

I should have the roofing samples back by this Thursday, November 10, 2016.

Sincerely,

Project Manager

KAS/bls