



Department of Public Works
Engineering Division
Robert F. Phillips, P.E., City Engineer
City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4751
Fax: (608) 264-9275
engineering@cityofmadison.com
www.cityofmadison.com/engineering

February 22, 2017

Assistant City Engineer
Michael R. Dailey, P.E.
Principal Engineer 2
Gregory T. Fries, P.E.
Christopher J. Petykowski, P.E.
Principal Engineer 1
Christina M. Bachmann, P.E.
Eric L. Dundee, P.E.
John S. Fahrney, P.E.
Facilities & Sustainability
Jeanne E. Hoffman, Manager
Operations Manager
Kathleen M. Cryan
Mapping Section Manager
Eric T. Pederson, P.S.
Financial Manager
Steven B. Danner-Rivers

**NOTICE OF ADDENDUM
ADDENDUM NO. 2**

**CONTRACT NO. 7911, PROJECT NO. 10457
Storm Sewer and Trench Patching at West Transfer Station**

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:


<http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 receive the material by another route.

Sincerely,

Robert F. Phillips, P.E., City Engineer

Cc: Mike Dailey



Office of City Engineering
City Engineering
Room 115, City County Building
210 Martin Luther King Jr. Boulevard
Madison, WI 53703-3346
TEL: 608/266-4751 FAX: 608/264-9275
Website: www.cityofmadison.com/engineering.html

ADDENDUM NO. 2
City of Madison, Engineering Department

CONTRACT NO. 7911
Storm Sewer and Trench Patching at West Transfer Station

This addendum is issued to modify, explain or correct the original Drawings, Specifications, or Contract Documents marked as *Storm Sewer and Trench Patching at West Transfer Station, City of Madison, Contract #7911, as issued on February 9, 2017* and is hereby made a part of the contract documents.

Please attach these Addendum documents to the Drawings and Project manual in your possession.

1. **Exhibit A Conceptual Plan Set**

- A. Correct note 5 on sheet 3 to read as follows; "Patching around all building posts shall be by Others."

2. **Special Provisions**

- A. Modify Article 104 Scope of work. Paragraph 2 as indicated here:

This contract (7911) is for excavation, storm sewer installation, base, and new pavements as noted in the plans and these special provisions. Excavation shall include the excavation of the electrical trench for the electrical contractor. Excavation for building post holes shall be by Others. ~~patching of the building post holes shall be by this contract.~~ This contract shall include complete installation of all safety bollards and asphalt patching noted in the plans.

- B. ADD the following bullet to Safety Bollards paragraph in Section 106.1 Source of Supply and Quality:

"• Bollard pipes at overhead doors shall be located no closer than 15" from building framing to provide Building Contractor with sufficient room for fastening siding to the framing."

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on Bid Express at <https://www.bidexpress.com/> and the City of Madison web site at <http://www.cityofmadison.com/business/PW/contracts/openforBid.cfm>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 to receive the material by another method.

For questions regarding this bid, contact:

Randy Wiesner
City of Madison Engineering
Phone: 608-243-5891
Fax: 608-264-9275
Email: rwiesner@cityofmadison.com