



Department of Public Works
Engineering Division
Robert F. Phillips, P.E., City Engineer

City-County Building, Room 115
210 Martin Luther King, Jr. Boulevard
Madison, Wisconsin 53703
Phone: (608) 266-4751
Fax: (608) 264-9275
engineering@cityofmadison.com
www.cityofmadison.com/engineering

Assistant City Engineer
Michael R. Dailey, P.E.

Principal Engineer 2
Gregory T. Fries, P.E.
Christopher J. Petykowski, P.E.

Principal Engineer 1
Christina M. Bachmann, P.E.
Eric L. Dundee, P.E.
John S. Fahrney, P.E.

Facilities & Sustainability
Jeanne E. Hoffman, Manager

Operations Manager
Kathleen M. Cryan

Mapping Section Manager
Eric T. Pederson, P.S.

Financial Manager
Steven B. Danner-Rivers

April 4, 2017

**NOTICE OF ADDENDUM
ADDENDUM 2**

CONTRACT NO. 7917

**PENN PARK SHELTER RENOVATION
AND CONCESSION/RESTROOM BUILDING**

Revise and amend the contract document(s) for the above project as stated in this addendum, otherwise, the original document shall remain in effect.

Spec Section 08 71 00-Door Hardware, Part 3-Execution, 3.2 Hardware Schedule, A Hardware Set HS-1 (toilets 102, 103)

Remove: Push/Pull

Add: Lock Set L-2 at each restroom door (keep L-3 Deadbolt)

Add: Von Duprin 6211 heavy-duty electric strike, 24 volt and all necessary conduit and wiring back to control panel in Mechanical Room for complete system.

Drawing A100 Finish Plan 2

At Toilet 102, Add the following note: "Epoxy Floor"

Drawing A100B Floor Plan 2

At note for New Concrete Slab, add the following note: "4" concrete slab reinforced with 6x6 W2.1/2.1 woven wire mesh"

Drawing A300B and Drawing A301B Elevation 1 and 2

At note for New Concrete Slab, add the following note: "4" concrete slab reinforced with 6x6 W2.1/2.1 woven wire mesh"

Drawing C101 Site Utility Plan

At Keynote 1 change 3" DIP to 4" DIP from existing 6" water lateral to proposed concession building.

Drawing P100 Floor Plan – Plumbing 2

In Concession 104, add trench drain, location as indicated on A100 Floor Plan

END OF ADDENDUM

April 5, 2017
Page 2

Please acknowledge this addendum on page E1 of the contract documents and/or in Section E: Bidder's Acknowledgement on Bid Express.

Electronic version of these documents can be found on the Bid Express web site at:

<http://www.bidexpress.com>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 to receive the material by another route.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert Phillips". The signature is written in a cursive style with large, looping letters.

Robert F. Phillips, P.E., City Engineer

Cc: Mike Dailey