



Department of Public Works  
**Engineering Division**  
Robert F. Phillips, P.E., City Engineer  
City-County Building, Room 115  
210 Martin Luther King, Jr. Boulevard  
Madison, Wisconsin 53703  
Phone: (608) 266-4751  
Fax: (608) 264-9275  
[engineering@cityofmadison.com](mailto:engineering@cityofmadison.com)  
[www.cityofmadison.com/engineering](http://www.cityofmadison.com/engineering)

**Deputy City Engineer**  
Gregory T. Fries, P.E.  
**Deputy Division Manager**  
Kathleen M. Cryan  
**Principal Engineer 2**  
Christopher J. Petykowski, P.E.  
John S. Fahrney, P.E.  
**Principal Engineer 1**  
Christina M. Bachmann, P.E.  
Mark D. Moder, P.E.  
Janet Schmidt, P.E.  
**Facilities & Sustainability**  
Jeanne E. Hoffman, Manager  
Bryan Cooper, Principal Architect  
**Mapping Section Manager**  
Eric T. Pederson, P.S.  
**Financial Manager**  
Steven B. Danner-Rivers

July 2, 2019

**NOTICE OF ADDENDUM  
ADDENDUM NO. 3  
City of Madison, Engineering Department**

**CONTRACT NO. 7769**

**SYCAMORE AVE. PUBLIC WORKS MAINTENANCE FACILITY-OFFICE REMODEL PROJECT**

This addendum is issued to modify, explain or correct the original Drawings, Specifications, or Contract Documents marked as **Sycamore Ave. Public Works Maintenance Facility – Office Remodel Project, City of Madison, Contract #7769, as issued on May 15, 2019** and is hereby made a part of the contract documents.

This addendum consists of the following documents:

- No Changes.

1. **GENERAL CONTRACT CONDITIONS**

A. Section A, Page A-1: A site/building visit has been added to the Pre Bid schedule on Monday, July 8<sup>th</sup>, 2019 at 9:00 - 10:30am. During this time prospective contractors may review site conditions at their own pace. Please note: The building will be operational at the time of the site/building visit.

2. **GENERAL QUESTIONS AND ANSWERS**

A. No Changes.

3. **ACCEPTABLE EQUIVALENTS**

A. No Changes.

4. **SPECIFICATIONS**

A. Prospective Contractor to provide the following concrete sealer as a Basis of Design. Refer to sheet A900 for additional information:

- Manufacturer:** BASF
- Product:** MasterProtect® H 440 HZ
- Note:** Contractor to prepare surfaces in accordance with manufacturer's instruction. Clean all surfaces of all sand, surface dust and dirt, oil, grease, chemical films and coatings, and other contaminants prior to application. Power wash, sandblast, or shotblast as necessary to achieve the desired surface condition.
- Note:** Acceptable equivalents will be evaluated subsequent to selection of a contractor

5. **DRAWINGS**

- A. Sheet A900 Finish Specifications.
  - i. For Conc Seal 1: Add the “BASF” as the manufacturer.
  - ii. For Conc Seal 1: Add the “MasterProtect H 440 HZ” as the product.
  - iii. For Conc Seal 1: Delete “Application:”

6. **PROPOSAL SPECIFICATIONS**

- A. No Change.

Please acknowledge this addendum in Section E on page E-1: Bidder’s Acknowledgement on Bid Express.

Electronic version of these documents can be found on Bid Express at <https://www.bidexpress.com/> and the City of Madison web site at <http://www.cityofmadison.com/business/PW/contracts/openforBid.cfm>

If you are unable to download plan revisions associated with the addendum, please contact the Engineering office at 608-266-4751 to receive the material by another method.

**For questions regarding this bid, contact:**

The Project Architect for this contract is: <u>Destree Design Architects</u> Jeremy Cynkar PH: 608-512-1883 Email: jcykar@destreearchitects.com	The City Project Manager for this contract is: <u>City of Madison</u> Brent Pauba PH: 608-266-4092 Email: bpauba@cityofmadison.com
---	--

Sincerely,



Robert F. Phillips, P.E., City Engineer